

Mailgram to N. C. Moseley from Tennessee Valley Authority dated February 5, 1975.

DISTRIBUTION:

50-260/75-5T

H. D. Thornburg, IE

IE:HQS (5)

Office of Standards Development

→ Central Files

Division of Reactor Licensing (13)

PDR

Local PDR

NSIC

TIC

STATE

As
(+)

h

MGHATLT HSB

3-030555E036 02/05/75

ICS IPMRNCZ CSP

2057298316 MGM TDRN DECATUR AL 100 02-05 0455P EST

ZIP

western union

Mailgram



US NUCLEAR REGULATORY COMMISSION
230 PEACHTREE ST NORTHWEST SUITE 818
ATLANTA GA 30303

BFAO 50-260/755T AT APPROXIMATELY 0900 HOURS FEBRUARY 5 1975 IT WAS DETERMINED THAT D DIESEL GENERATORS UNDER VOLTAGE START RHR SERVICE WATER PUMP D1 RHR PUMP 1D AND 2D AND CORE SPRAY PUMP 1D AND 2D AUTO START FEATURE HAD BEEN INOPERABLE FOR APPROXIMATELY 39 HOURS DURING A BATTERY CAPACITY DISCHARGE TEST UNIT 1 WAS IN A COLD SHUTDOWN CONDITION UNIT 2 WAS AT APPROXIMATELY 65 PERCENT POWER BATTERY CAPACITY TEST COMPLETED CONDITIONS NORMAL

H J GREEN BROWNS FERRY NUCLEAR PLANT

16:55 EDT

MGHATLT HSB