



**Consumers
Power
Company**

Palisades Nuclear Plant: Route 1, Box 178, Covert, Michigan 49043

June 23, 1976



USNuclear Regulatory Commission
Mail and Records Section
Washington, D.C., 20555


Re: LICENSE REPORTS OF MONTHLY OPERATING DATA
DPR-20, DOCKET NO. 50-255

Gentlemen:

Enclosed is a revised copy of Appendix E for the Palisades Nuclear Plant for the month of May, 1976.

William E. Adams
General Engineer

cc: JGKepler
RBDeWitt
RBSewell
DEVanFarowe, State of Mich.



Regulatory Docket File

6484

APPENDIX E
UNIT SHUTDOWNS

CORRECTED

DOCKET NO. 50-255

UNIT NAME Palisades

DATE 6-23-76

COMPLETED BY DIBollnow

REPORT MONTH May 1976

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
10	751220	S	280.4	C	3	Item #1 is a Continuing Refueling Outage as Item #10
1		S	2240.7	C	3	
2	750509	F	.5	A	Remained Critical	Repair a Secondary Relief Valve
3	750510	F	7.1	A	#3	Loss of Feedwater Pump
4	750512	F	146.1	A	1	Repair CRDM Seal Leakage
						(1) REASON A-EQUIPMENT FAILURE (EXPLAIN) B- MAINT. OR TEST C- REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN) (2) METHOD 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM

SUMMARY:

1.16-E-1