



**Consumers
Power
Company**

78-000

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

March 23, 1978

Mr James G Keppler
Office of Inspection and Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

US NRC
DISTRIBUTION SERVICES
BRANCH

1978 APR 10 AM 10 18

RECEIVED DISTRIBUTION
SERVICES UNIT

REGULATORY DOCKET FILE COPY

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - CANCELLATION
OF EVENT REPORT

Telephone and TWX reports to the NRC Region III IE office on February 23 and 24, 1978 identified a potential 14-day reportable occurrence at the Palisades Plant.

Subsequent evaluation has resulted in the determination that the inventory of water in the SIRW tank was sufficient to consider the tank as a valid source of borated water. In addition, the valves between the SIRW tank and the primary coolant system were verified to be in the proper positions to permit remote initiation of boric acid flow to the reactor.

Accordingly, this event report is being canceled.

David P Hoffman
Assistant Nuclear Licensing Administrator

CC: Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement

MAR 27 1978

A002
110