

1975 SEP 8 AM 10 01

0

WU AGCY WHEA

WU MVN ILL

WHA55 R C 100 CDT

(VEA047(0949)(1-406326A251)PD 09/08/75 0946

TLX CONSPower JKN

CCIC 023 DLY JACKSON MICH 9/8/75

PMS MR K R BAKER

NRC (FORMERLY THE ATOMIC ENERGY COMMISSION)

REGION III

709 ROOSEVELT ROAD

ELEN ELIYN, IL

SUBJECT- PALISADES PLANT - ABNORMAL OCCURRENCE 75-20

CONFIRMING OUR TELECON WITH K R BAKER ON FRIDAY, 9/5/75, WE EXPERIENCED A DROPPED CONTROL ROD NO. 16 ABOUT NOON FRIDAY. THIS INCIDENT IS CLASSIFIED AS AO 75-20 BASED ON TECH SPECS 3.10.5C SHUTDOWN ROD INSERTED BEYOND EXERCISE LIMIT. FLUX TILT

AND EJECTED ROD WORTH RESULTING FROM DROPPED ROD WERE WITHIN TECH SPECS LIMITS. THE PLANT WAS SHUT DOWN FRIDAY NIGHT FOR CLUTCH COIL REPLACEMENT.

J E LEWIS

PALISADES PLANT

CONSUMERS POWER COMPANY

CRV

WU MVN ILL

WU AGCY WHEA

SEP - 8 1975

50-255

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

50-255

Sept 8, 1975

A. IE Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:

IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:

IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files  
IE Chief, M&PPB  
L:D/D for Reactor Project

B. IE Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:

IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:

IE Chief, FS&EB  
IE:HQ  
DR Central Files  
IE Files

C. Incident Notification From: Consumers Power Company 50-255  
(Licensee & Docket No. (or License No.))

Transmittal Date : September 8, 1975 Palisades Plant

Distribution:

IE Chief, FS&EB  
IE:HQ (4)  
Licensing (4)  
DR Central Files  
IE Files

Distribution:

IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files



DOE  
4