



Telegram

JUL 14 PM 1:05

VEA130(1308)(1-019949C195)PD 07/14/75 1305

TLX CONSPower JKN

ZCZC 002 DLY JACKSON MICHIGAN 7-14-75

PMS USNRC

MR KEN BAKER

NUCLEAR REGULATORY COMMISSION

REGION III.

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

50-255

00285

AC 312  
TELEPHONE NO. 3-2  
TELETYPE NO. 4B-3  
DATE 7/14  
ATTEMPTS 210P  
858-2660  
BY 45

THIS TWX IS TO DOCUMENT OUR TELEPHONE CONVERSATION ON 7-13-75, WHICH WAS TO REPORT THE INOPERABLE STATUS OF CONTROL ROD NO 27. THIS INCIDENT WILL BE REPORTED AS AN UNUSUAL EVENT, CODE NUMBER UE-75-7, TITLED, "CONTROL ROD FAILURE TO INSERT." THIS TWX WILL BE FOLLOWED BY A FORMAL REPORT AS REQUIRED BY TECH SPEC

SF-1201 (R5-68) 5.8.1.E.

CC: R B SEWELL

K W BERRY

PALISADES NUCLEAR PLANT  
CONSUMERS POWER COMPANY

ALL CH

NNNN

SF-1201 (R5-69)



Telegram

VEA072(1008)(1-009792C203)PD 07/22/75 1004

TLX CONSPower JKN

ZCZC 001 DLY JACKSON MICHIGAN 7-22-75

PMS MR KEN BAKER

USNRC

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

SUBJECT: PALISADES PLANT  
ABNORMAL OCCURRENCE

1975 JUL 22 11:10  
AC 312 BOOK NO 3-2  
TELEPHONE NBR. 858-2660  
TELEPHONED TO 858-2660  
DATE DLD. 7/22/75 TIME 1203P  
ATTEMPTS TO DELIVER: 1

MOV - 3011 IMPROPER OPERATION

50-255

THIS MESSAGE IS TO CORRECT A CONVERSATION MR G B SLADE HAD WITH YOU  
1725 HOURS, JULY 19, 1975 CONCERNING AN ABNORMAL OCCURRENCE AT

SF-1201 (R5-69)

PALISADES RELATING TO THE IMPROPER FUNCTIONING OF THE MOV-3011 DURING THE QO-1 TEST PER PRC 75-41 - 7-21-75. THIS OCCURRENCE WAS DETERMINED NOT TO BE AN ABNORMAL OCCURRENCE AS REPORTED BUT AN UNUSAL EVET - UE 75-6. DETAILS WILL BE PRESENTED IN THE FORMAL REPORT.

PER YOUR REQUEST THE SWITCH THAT FAILED WAS - GE TYPE CR 2940 - SPRING RETURN - BAT LEVER OPERATION.

CORRECTION - SHOULD BE EVENT - UE 75-6.

CC: R B SEWELL

D K POWERS/J G LEWIS

PALISADES PLANT

JUL 24 1975

SF-1201 (R5-69)

CONSUMERS POWER CO

ALL HO

NNNN

D(

TB(

) LR(

Telegram



VEC185(1532)(1-030255A206)PD 07/25/75 1529 PM 3:36

TLX CONSPower JKN

ZCZC 00005 JACKSON MICH 7/25/75

PMS KEN BAKER

NUCLEAR REGULATORY COMMISSION

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

AC 312 BOOK NO. 3-2 LB3

OPR. NO.

TELEPHONE NBR. 858-2660

TELEPHONED TO BL

BY 36

DATE DLD. 07-25 TIME 438P

ATTEMPTS TO DELIVER:

50-255

PALISADES NUCLEAR PLANT IS DECLARING ITSELF UNDER ABNORMAL OPERATING CONDITIONS AS SPECIFIED IN TECH SPEC SECTION 5-2.2 AS OF 7-16-75. THE T-91 TANK UTILITY WATER STORAGE TANK WAS REMOVED FROM NORMAL SERVICE TO REPLACE THE LINER COATING. THE COATING MODIFICATION WILL TAKE APPROXIMATELY FOUR WEEKS. THE T-90 TANK, PRIMARY SYSTEM MAKE-UP STORAGE TANK, WILL ALSO HAVE A COATING MODIFICATION IN THE

SF-1201 (RS-69)

NEAR FUTURE. THESE TANKS BEING OUT OF SERVICE MAKES NORMAL OPERATION IMPOSSIBLE.

J G LEWIS/T P NEAL

CONSUMERS POWER COMPANY

PALISADES NUCLEAR PLANT

CBW

CC: R B SEWELL

J L BACON

NNNN

JUL 2 1975

SF-1201 (RS-69)

Wheaton PTR

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

A. IE Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files  
IE Chief, M&PPB  
L:D/D for Reactor Project

B. IE Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ  
DR Central Files  
IE Files

C. Incident Notification From: Consumers Power Company 50-255  
(Licensee & Docket No. (or License No.))

Transmittal Date : July 31, 1975 Palisades Plant

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
Licensing (4)  
DR Central Files  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files

