



**Consumers  
Power  
Company**

*Central Mail*

**COPY**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

August 3, 1976

Mr James G. Keppler  
Office of Inspection and Enforcement  
Region III  
US Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DOCKET 50-255, LICENSE DPR-20  
PALISADES PLANT, RELIEF VALVES

Your letter dated July 21, 1976 transmitted IE Bulletin No 76-06 and requested information concerning diaphragm operated relief valves on safety-related systems. A review of our Palisades Plant determined that we have no diaphragm operated relief valves on safety-related high temperature fluid systems. We conclude that no further action is required.

David A. Bixel (Signed)

David A. Bixel  
Assistant Nuclear Licensing Administrator

CC: Office of Inspection and Enforcement  
Division of Reactor Inspection Program

*9*

AUG 5 1976