

SCREENING/EVALUATION SHEET
FOR LICENSEE REPORTS OF NON-ROUTINE EVENTS

AO _____

IDENTIFICATION

Name (Facility or Licensee): Palisades
Docket No: 50-255 License No: DPR-20 Event Date: 6/14/76
Event Description: Accident Analysis For Simultaneous
loss of 4 reactor coolant pumps
Notification Date: 6/15 Time: 1430 Method: Phone
Notified By: G Allen Notification Received By: KRS
Regulation Requiring the Report: 7/5

PRELIMINARY RESPONSE

Importance Category and Response Level: I _____, II _____, III X, Other _____
Immediate Site/Insp/Invest Required: No Report No: _____
Immediate Notifications: Individual _____ Date and Time Notified _____
NRC:HQ _____
State _____
Radiological Team _____
Other _____
Press Release: _____ Issued by Licensee (Date) _____
Issued by NRC (Date) _____

SCREENING

The Licensee reports that during a review of potential problems if flooding occurred in the turbine building it was noted that both 4160v buses could be flooded at the same time as they are located side by side in the turbine building. These buses are not ECCS related but do supply power to the Primary Coolant Pumps. The PSA states that the loss of four Primary Coolant Pumps is not considered credible and therefore was not analyzed in the safety analysis. Additional analysis is being conducted. In the interim the Licensee has instituted administrative procedures to require plant trip if flooding occurs. Flooding alarms at lower elevation in turbine building are being tested to insure their operability. Additional temporary flooding protection is being considered. The Licensee will provide a 14 day report.

Red 3:06 LS

6/15

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date: June 18, 1976 Palisades Power Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files