



telegram

VEB091(0952)(1-007469C132)PD 05/11/1976 01:19:53 AM 9:53

TLX CONSPower JKN

ZCZC 008 JACKSON MICH 5/11/76

PMS MR K R BAKER

NUCLEAR REGULATORY COMM (FORMERLY AEC)

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

AC 3/2 4B3 OFR. NO. 24
TELEPHONE NR. 858-2660
TELEPHONED TO FDK BY 134
DATE DLD. 05-11 TIME 1121A

ATTEMPTS TO DELIVER:
Requested msg just to be mailed.
mail

PALISADES PLANT - EVENT REPORT PAL -76-014

THIS MESSAGE IS SENT TO CONFIRM OUR CONVERSATION (5/11/76) ABOUT A PROMPT REPORTABLE OCCURRENCE (PAL-ER-014). THE OCCURRENCE INVOLVED REMOVING THE 1-1 DIESEL FROM SERVICE WHILE ONE OF THE HIGH-PRESSURE SAFETY INJECTION PUMPS ON THE OPPOSITE BUS WAS INOPERABLE. THIS IS

SF-1201 (R5-69)

MAY 14 1976

CONSIDERED REPORTABLE SINCE THE UNIT WAS IN OPERATION WHEN AN OPERATION SUBJECT TO A LIMITING CONDITION WAS LESS CONSERVATIVE THAN THE LEAST CONSERVATIVE ASPECT OF THE LIMITING CONDITION FOR OPERATION ESTABLISHED IN THE TECHNICAL SPECIFICATIONS.

J G LEWIS/G B SLADE

PALISADES PLANT

CONSUMERS POWER COMPANY

CBW

NNNN

SF-1201 (R5-69)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

15 69147

6/4/76

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date: June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files