

am
western union

Telegram

western union

Telegram

western union

am

5/11 9:00

M
WU AGCY WHEA

WU MVN ILL

WUA 027 GE 805A CDT

VED054(0754)(1-002718C132)PD 05/11/76 0750

TLX CONSPower JKN

ZCZC 001 DLY JACKSON MICHIGAN 5-11-76

PMS US NUCLEAR REGULATORY COM

(FORMERLY US ATOMIC ENERGY COMMISSION)

MR K R BAKER

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

SUBJECT PALISADES PLANT -
EVENT REPORT PAL-76-013

THIS IS TO NOTIFY YOU OF REPORTABLE EVENT PAL-76-013 AT PALISADES PLANT, AS DISCUSSED WITH MR K R BAKER YESTERDAY. DURING PLANT START-UP OVER THE WEEKEND, A COOLING TOWER HAD TO BE DRAINED TO REPAIR A LEAKING CONDENSER TUBE. THE RESULTING TRANSIENTS CAUSED

A TEMPERATURE DIFFERENTIAL TO THE LAKE IN EXCESS OF THE 5 DEGREE LIMIT OF TECH SPECS 3.9.9 ON THREE OCCASIONS PRIOR TO RESTORATION OF TOWER OPERATION.

CC R B DE WITT
R B SEWELL

J G LEWIS
PALISADES NUCLEAR PLANT
CONSUMERS POWER COMPANY
ALL HO

NNNN

50-255
MAY 11 1976

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

6/4/76

~~7/1/76~~

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date: June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files