

am  
western union  
Telegram  
western union  
Telegram  
western union  
Telegram  
western union

5/17 1200

MV  
WU AGCY WHEA

WU MVN ILL

WUA106 HH 1200P CDT

VEB085(1042)(1-008804C138)PD 05/17/76 1039

TLX CONSPower JKN

ZCZC 0001 DLY JACKSON MICHIGAN 5-17-76

PMS US NUCLEAR REGULATORY COM  
(FORMERLY US ATOMIC ENERGY COM)

MR J G KEEPLER

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

SUBJECT CONFIRMATION OF PROMPT REPORTABLE EVENT  
MSIV VALVE INTEGRITY (ER-PAL-76-16)

THIS IS TO CONFIRM MY TELEPHONE REPORT ON MAY 14, 1976 WITH MR E  
JORDAN, CONCERNING THE PRELIMINARY RESULTS OF AN ANALYSIS OF THE  
PALISADES MSIVS. WE HAVE CONCLUDED THAT VALVE INTEGRITY MAY BE  
LOST, IN THE EVENT OF A MAIN STEAM LINE BREAK, FOR THE VALVE ASSOCI-  
ATED WITH THE BREAK. A REVIEW OF THE PALISADES FSAR SHOWS THAT THE

STEAM LINE RUPTURE INCIDENT ASSUMED COMPLETE BLOWDOWN OF THE STEAM  
GENERATOR ASSOCIATED WITH THE STEAM LINE BREAK AND, THEREFORE, THAT  
THIS TYPE OF INCIDENT HAS BEEN REVIEWED.

D A BIXEL  
NUCLEAR LICENSING  
CONSUMERS POWER CO  
ALL HO  
:  
WU AGCY WHEA

MAY 18 1976

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

6/4/76

Incident Notification From: Consumers Power Company (50-255)  
(Licensee & Docket No. (or License No.))

Transmittal Date: June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB  
IE Chief, FC&EB  
IE:HQ(4)  
Licensing(4)  
DR Central Files  
IE Files

Distribution:

IE Chief, FOSB  
IE Chief, FC&EB  
IE:HQ(4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files