

MGMCGBT HSA
1-032607A124 05/03/76
ICS IPMVEIB MVN
02179 MGM TDVE JACKSON MI 05-03

western union

Mailgram®



NUCLEAR REGULATORY COMMISSION
(FORMERLY AEC) BUILDING R-799 ROOSEVELT RD
GLENELLYN IL 60137

50-255

SUBJECT: CONFIRMATION OF A PROMPT REPORTABLE OCCURRENCE
ON APRIL 30, 1976, R B SEWELL REPORTED TO MR E JORDAN, BY TELEPHONE,
THAT DURING THE COURSE OF WORK ON MODIFICATIONS RELATED TO BORON
RECRYSTALLIZATION, THE VENDOR OF TWO VALVES CV2113 AND CV2115 HAS
REPORTED THAT IN ONE CASE CODE ALLOWABLE STRESS MAY BE EXCEEDED AT
THE VALVE BODY TO BONNET FLANGE, THIS CASE IS ASSOCIATED WITH 2200
PSI OPERATION AND THE ACT OF CLOSING THE VALVE. THE VENDORS CALCU-
LATIONS SHOW THAT THE VALVES ARE FULLY WITHIN CODE LIMITS FOR THE
PRESENTLY ALLOWED 1800 PSI OPERATING PRESSURE.
WE HAVE IDENTIFIED THIS AS A PROMPT REPORTABLE OCCURRENCE AND ARE
CONTINUING TO INVESTIGATE THIS PROBLEM

K W BERRY
PALISADES PLANT
CONSUMERS POWER CO
CBW

17113 EST

MGMCGBT HSA

MAY 4 1976

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

6/14/76

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date: June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files