



Telegram

VEC214(1733)(1-029921C114)PD 04/23/76 1730

TLX CONSPower JKN

ZCZC 002 DLY JACKSON MICHIGAN 4-23-76

PMS US NUCLEAR REGULATORY COM
(FORMERLY US ATOMIC ENERGY COM)

ATT: J G KEPPLER

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

30-255
AC 312 BOOK NO. OPR. NO.
TELEPHONE NBR. 858-2660
TELEPHONED TO 001.76 BY 117
DATE DLD. 04-23 TIME 452p
ATTEMPTS TO DELIVER: *Maid*

SUBJECT: EVENT REPORT PAL 76-011

ABNORMAL DEGRADATION OF PRIMARY CONTAINMENT DUE TO EXCEEDING LOCAL
LEAK TESTING ALLOWABLE LIMITS.

DURING ITS LEAK TESTING THE PENETRATION NUMBER 46 CONTAINMENT
VENT HEADER - WAS FOUND TO EXCEED ITS ALLOWABLE LIMITS.

SF-1201 (R5-69)

APR 27 1976

WE FIND THIS IS REPORTABLE UNDER PALISADES TECHNICAL SPECIFICATIONS
6.9.2.A "3" - REPORTABLE OCCURRENCES.

CC: R B DE WITT, PARNALL
R B SEWELL, PARNALL

J G LEWIS/K W BERRY
CONSUMERS POWER COMPANY
PALISADES NUCLEAR PLANT
ALL HO

C

SF-1201 (R5-69)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

6/14/76

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date: June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files