



**Consumers  
Power  
Company**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

May 25, 1976



Mr James G. Keppler  
Office of Inspection Enforcement  
Region III  
US Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DOCKET 50-255, LICENSE DPR-20 -  
PALISADES PLANT ER-76-12 -  
DIESEL GENERATOR & HPSI PUMP OUT OF SERVICE

Attached is a reportable occurrence which relates to the Palisades Plant. This occurrence has been classified as operation when an operation subject to a limiting condition is less conservative than the least conservative aspect of the limiting condition for operation established in the Technical Specifications.

Please note that this report is being submitted one day late per my telephone conversation with Ken Baker.

*David A. Bixel*

David A. Bixel  
Assistant Nuclear Licensing Administrator



Regulatory Docket File

5812

JUN 7 1976

# LICENSEE EVENT REPORT

CONTROL BLOCK:                  

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME	LICENSE NUMBER	LICENSE TYPE	EVENT TYPE
<span style="border: 1px solid black; padding: 0 5px;">01</span> <span style="border: 1px solid black; padding: 0 5px;">M</span> <span style="border: 1px solid black; padding: 0 5px;">I</span> <span style="border: 1px solid black; padding: 0 5px;">P</span> <span style="border: 1px solid black; padding: 0 5px;">A</span> <span style="border: 1px solid black; padding: 0 5px;">L</span> <span style="border: 1px solid black; padding: 0 5px;">L</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">-</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">-</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span>	<span style="border: 1px solid black; padding: 0 5px;">4</span> <span style="border: 1px solid black; padding: 0 5px;">1</span> <span style="border: 1px solid black; padding: 0 5px;">1</span> <span style="border: 1px solid black; padding: 0 5px;">1</span> <span style="border: 1px solid black; padding: 0 5px;">1</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">1</span>

REPORT TYPE	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
<span style="border: 1px solid black; padding: 0 5px;">01</span> CON'T <span style="border: 1px solid black; padding: 0 5px;">  </span> <span style="border: 1px solid black; padding: 0 5px;">  </span>	<span style="border: 1px solid black; padding: 0 5px;">T</span> <span style="border: 1px solid black; padding: 0 5px;">L</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">-</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">2</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">5</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">1</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">7</span> <span style="border: 1px solid black; padding: 0 5px;">6</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">2</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">7</span> <span style="border: 1px solid black; padding: 0 5px;">6</span>

## EVENT DESCRIPTION

02 Diesel Generator 1-1 was made inoperable for preventative maintenance while one of

03 two HPSI pumps, associated with the operable diesel, was inoperable. Corrective

04 action taken has involved both a review of this event by the Supervisor involved

05 and review of possible procedure changes which would utilize a checklist for remov-

06 ing safety-related equipment from service. We expect procedure changes (ER-76-14)

SYSTEM CODE	CAUSE CODE	COMPONENT CODE	PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER	VIOLATION
<span style="border: 1px solid black; padding: 0 5px;">07</span> <span style="border: 1px solid black; padding: 0 5px;">E</span> <span style="border: 1px solid black; padding: 0 5px;">E</span>	<span style="border: 1px solid black; padding: 0 5px;">A</span>	<span style="border: 1px solid black; padding: 0 5px;">G</span> <span style="border: 1px solid black; padding: 0 5px;">E</span> <span style="border: 1px solid black; padding: 0 5px;">N</span> <span style="border: 1px solid black; padding: 0 5px;">E</span> <span style="border: 1px solid black; padding: 0 5px;">R</span> <span style="border: 1px solid black; padding: 0 5px;">A</span>	<span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">Z</span> <span style="border: 1px solid black; padding: 0 5px;">9</span> <span style="border: 1px solid black; padding: 0 5px;">9</span> <span style="border: 1px solid black; padding: 0 5px;">9</span>	<span style="border: 1px solid black; padding: 0 5px;">Y</span>

## CAUSE DESCRIPTION

08 The cause of this event was an oversight by the operations staff.

09

10

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">11</span> <span style="border: 1px solid black; padding: 0 5px;">C</span>	<span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">2</span> <span style="border: 1px solid black; padding: 0 5px;">5</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>	<span style="border: 1px solid black; padding: 0 5px;">a</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>

  

FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
<span style="border: 1px solid black; padding: 0 5px;">12</span> <span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>

## PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">13</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span>	<span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>

## PERSONNEL INJURIES

NUMBER	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">14</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>

## PROBABLE CONSEQUENCES

15 None, a redundant pump was available.

## LOSS OR DAMAGE TO FACILITY

TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">16</span> <span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>

## PUBLICITY

17 NA

## ADDITIONAL FACTORS

18 (Description contd) to be completed by July 1, 1976.

19