

WU BVM ILL

WU MUN ILL

1975 NOV 14 PM 5 43

WU AGCY WHEA

WUA264 BGS 538P

VEE238(1818)(1-034478A318)PD 11/14/75 1813

TLX CONSPower JKN

ZCZC 009 DLY JACKSON MICHIGAN 11-14-75

PMS US NUCLEAR REGULATORY COM

(FORMERLY US ATOMIC ENERGY COM)

K R BAKER

REGION III

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

THIS IS TO CONFIRM A TELECON WITH K R BAKER YESTERDAY NOVEMBER 13, 1975, CONCERNING AN ABNORMAL OCCURRENCE AT PALISADES NUCLEAR PLANT. DURING ROUTINE LEAK TESTING OF CB EXHAUST VALVES LEAKAGE IN EXCESS OF TOTAL ALLOWABLE 60.000 CC/MIN WAS DISCOVERED. WE HAVE DETERMINED THE LEAK TO BE BACK THROUGH

W THE INSIDE VALVE TO THE CB. WE HAVE

SOAP TESTED THE OUTSIDE VALVE TO PROVE NO LEAKAGE AND WILL TAG BOTH VALVES SHUT UNTIL THE PLANT IS SHUTDOWN TO ALLOW REPAIR.

CC. R B DE WITT
R B SEWELL

THE PREVIOUS SENT TO J G LEWIS WAS INAVERTENTLY A MISTAKE

SHOULD HAVE GONE TO K R BAKER SORRY ABOUT SO PLEASE DISREGARD
THE PREVIOUS WIRE SENT AT 1752. THANK YOU.

J G LEWIS
PALISADES PLANT
CONSUMERS POWER CO

212 W MICHIGAN AVE

ALL HQ



WU AGCY WHEA

WJ MVN ILL

11-17-75

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Consumers Power Company ,50-255
(Licensee & Docket No. (or License No.))

Transmittal Date : December 4, 1975 Palisades Plant

Distribution:
IE Chief, FC&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FC&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files

