



Telegram

VEA117(1223)(1-015271C233)PD 10/15/75 1220

OCT 15 PM 12:25

TLX CONSPower JKN

ZCZC 005 DLY JACKSON MICHIGAN 10/15/75

PMS US NUCLEAR REGULATORY COMMISSION
(FORMERLY AEC)

MR K R BAKER

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

SUBJECT - PALISADES PLANT -

ABNORMAL OCCURRENCE REPORT

60225
AC 312 BOOK NO. GPR. NO.
TELEPHONE NO. 858-2600
TELEPHONES TO M.S. AT 39
DATE DLD 10/15 TIME 1247P
ATTEMPTS TO DELIVER:

THIS TWX CONFIRMS MY TELEPHONE CONVERSATION WITH K. R. BAKER
ON OCTOBER 15, 1975 IN WHICH I REPORTED AN ABNORMAL OCCURRENCE
AT PALISADES. THE DISCHARGE TEMPERATURE OF WATER FROM THE
MIXING BASIN WAS IN EXCESS OF THE 5 DEGREES ALLOWED BY TECH

SF-1201 (R5-69)

OCT 17 1975

SPECS FOR A PERIOD OF ABOUT 1.5 HOURS WHILE A DIVER WAS INSTALL-
ING TEMPERATURE MONITORING EQUIPMENT.

CC: R B DEWITT

R B SEWELL

G B SLADE

CONSUMERS POWER COMPANY

212 W MICHIGAN AVENUE

ALL DBW

NNNN

SF-1201 (R5-69)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date : Palisades Plant October 20, 1975

Distribution:
IE Chief, FC&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FC&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files



104