



PSEG

22
REGULATORY DOCKET FILE COPY

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

January 18, 1978

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. George Lear, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Gentlemen:

IN-SERVICE INSPECTION AND TESTING PROGRAMS
UNIT NO. 1
DOCKET NO. 50-272
SALEM NUCLEAR GENERATING STATION



In our letter of October 11, 1977 on In-service Inspection and Testing Program, Footnote 1 of Attachment 1, Table 2; was incomplete. Please replace Table 2 with the attached revision.

If you require additional information or clarification, please contact us.

Very truly yours,

F. P. Librizzi
General Manager -
Electric Production

A001/S
1/40*

TABLE 2
CLASS 2 COMPONENTS, PARTS, AND METHODS OF EXAMINATION

Item No.	Examination Category Table IWC-2520	Components and Parts to be Examined	Method
Pressure Vessels ¹			
C1.1	C-A	Circumferential butt welds	Volumetric
C1.2	C-B	Nozzle-to-vessel welds	Volumetric
C1.3	C-C	Integrally-welded supports	Surface
C1.4	C-D	Pressure-retaining bolting	Visual and either surface or volumetric
Piping			
C2.1	C-F, C-G	Circumferential butt welds	Volumetric
C2.2	C-F, C-G	Longitudinal weld joints in fittings	Volumetric
C2.3	C-F, C-G	Branch pipe-to-pipe weld joints	Volumetric
C2.4	C-D	Pressure-retaining bolting	Visual and either surface or volumetric
C2.5	C-E-1	Integrally-welded supports	Surface
C2.6	C-E-2	Support components	Visual
Pumps ¹			
C3.1	C-F, C-G	Pump casing welds	Volumetric
C3.2	C-D	Pressure-retaining bolting	Visual and either surface or volumetric
C3.3	C-E-1	Integrally-welded supports	Surface
C3.4	C-E-2	Support components	Visual
Valves			
C4.1	C-F, C-G	No components within this category	-
C4.2	C-D	Pressure-retaining bolting	Visual and either surface or volumetric
C4.3	C-E-1	Integrally-welded supports	Surface
C4.4	C-E-2	Support components	Visual

¹ Class 2 Components (subject to the exemption criteria of IWC 1220)

Charging Safety Injection Pumps 11, 12, and 13
 No. 1 Reactor Coolant Filter
 No. 1 Excess Letdown Heat Exchanger (Tube Side)
 No. 1 Regenerative Heat Exchanger
 No. 1 Letdown Heat Exchanger (Tube Side)
 Accumulators 11, 12, 13, and 14
 Boron Injection Tank
 Refueling Water Tank
 Safety Injection Pumps 11 and 12
 RHR Heat Exchangers 11 and 12
 RHR Pumps 11 and 12
 Chemical Volume and Control Tank
 Head Tanks 11, 12, 13 and 14
 Refueling Water Storage Tank Heat Exchanger
 Refueling Water Storage Tank Heating Water Recirc. Pump
 Containment Spray Pumps 11 and 12
 Steam Generators 11, 12, 13 and 14 (Shell Side)