

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY
VICE PRESIDENT AND GENERAL COUNSEL

MALCOLM H. FURBUSH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
RICHARD A. CLARKE
JOHN B. GIBSON
ASSISTANT GENERAL COUNSEL

November 9, 1977

GILBERT L. HARRICK
GLENN WEST, JR.
CHARLES W. THISELL
DANIEL E. GIBSON
JOSEPH I. KELLY
HOWARD V. GOLUB

EDWARD J. MCGANNNEY
ARTHUR L. MILLMAN, JR.
ROBERT OHLBACH
DAN GRAYSON LUBROCK
JACK F. FALLIN, JR.

SENIOR COUNSEL

JOSHUA BAR-LEV
ROBERT L. BORDON
LEIGH S. CASSIDY
BRIAN B. DENTON
DARY P. ENGINAS
DONALD ERICKSON
DAVID C. GILBERT
ANNETTE GREEN
ROBERT L. HARRIS
KERMIT R. KUBITZ
THEODORE L. LINDBERG, JR.
RICHARD F. LOCKE
HARRY W. LONG, JR.
RICHARD H. MOSS
J. MICHAEL REIDENRACH
IVOR E. SAMSON
SUE ANN LEVIN SCHIFF
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

J. PETER BAUMGARTNER
STEVEN P. BURKE
BERNARD J. DELLASANTA
WILLIAM H. EDWARDS
JOSEPH S. ENGLERT, JR.
JOHN N. FRYE
BARBARA A. GOODE
PETER W. HANSCHEN
JUAN M. JAYO
F. RONALD LAUPHEIMER
MERCK E. LIPSON
JAMES C. LOSDON
RICHARD L. MEISS
DOUGLAS A. OGLEBY
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JACK W. SHUCK
SHIRLEY A. WOOD

ATTORNEYS

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
Region V
U.S. Nuclear Regulatory Commission
1990 N. California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94596

Re: Docket No. 50-275-OL
Docket NO. 50-323-OL
Diablo Canyon Units 1 and 2

Dear Mr. Engelken:

This is in response to your letter dated September 12, 1977, which enclosed I.E. Bulletin No. 77-03 and requested information concerning on-line testing of the Westinghouse Solid State Protection System (SSPS).

We intend to modify our existing Surveillance Test Procedures (M-16 series) for the SSPS to insure that the reset, block, and timing features are adequately tested. We expect to have this revision implemented prior to the next scheduled performance of these surveillance tests, which is currently planned for February 1, 1978. We are also reviewing our test procedures to insure that all critical portions of the system are adequately tested.

Very truly yours,

Philip A. Crane, Jr.

DLPolley:vm