



FEB 22 2019

Michael J. Yox
Regulatory Affairs Director
Vogtle 3 & 4

7825 River Road
Waynesboro, GA 30830
706-848-6459 tel

Docket Nos.: 52-025
52-026

ND-19-0190
10 CFR 52.99(c)(3)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3 and Unit 4
Notice of Uncompleted ITAAC 225-days Prior to Initial Fuel Load
Item 2.3.14.04 [Index Number 480]

Ladies and Gentlemen:


Pursuant to 10 CFR 52.99(c)(3), Southern Nuclear Operating Company hereby notifies the NRC that as of February 21, 2019, Vogtle Electric Generating Plant (VEGP) Unit 3 and Unit 4 Uncompleted Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.3.14.04 [Index Number 480] has not been completed greater than 225-days prior to initial fuel load. The Enclosure describes the plan for completing this ITAAC. Southern Nuclear Operating Company will, at a later date, provide additional notifications for ITAAC that have not been completed 225-days prior to initial fuel load.

This notification is informed by the guidance described in NEI 08-01, *Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52*, which was endorsed by the NRC in Regulatory Guide 1.215. In accordance with NEI 08-01, this notification includes ITAAC for which required inspections, tests, or analyses have not been performed or have been only partially completed. All ITAAC will be fully completed and all Section 52.99(c)(1) ITAAC Closure Notifications will be submitted to NRC to support the Commission finding that all acceptance criteria are met prior to plant operation, as required by 10 CFR 52.103(g).

This letter contains no new NRC regulatory commitments.

If there are any questions, please contact Tom Petrak at 706-848-1575.

Respectfully submitted,


Michael J. Yox
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3 and Unit 4
Completion Plan for Uncompleted ITAAC 2.3.14.04 [Index Number 480]

MJY/LBP/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. D. A. Bost (w/o enclosures)

Mr. D. L. McKinney (w/o enclosures)

Mr. M. D. Meier (w/o enclosures)

Mr. D. H. Jones (w/o enclosures)

Mr. J. B. Klecha

Mr. G. Chick

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Mr. T. G. Petrak

Mr. W. A. Sparkman

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. J. L. Hughes

Ms. K. M. Stacy

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

Nuclear Regulatory Commission

Mr. W. Jones (w/o enclosures)

Mr. F. D. Brown

Ms. J. M. Heisserer

Mr. C. P. Patel

Mr. G. J. Khouri

Ms. S. E. Temple

Mr. N. D. Karlovich

Mr. A. Lerch

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Covert

Mr. C. Welch

Mr. I. Cozens

Mr. J. Gaslevic

Mr. V. Hall

Oglethorpe Power Corporation

Mr. R. B. Brinkman

Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller

Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani (w/o enclosures)

Mr. D. C. Durham (w/o enclosures)

Mr. M. M. Corletti

Ms. L. G. Iller

Ms. J. Monahan

Mr. J. L. Coward

Other

Mr. J. E. Hesler, *Bechtel Power Corporation*

Ms. L. Matis, *Tetra Tech NUS, Inc.*

Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*

Mr. S. Roetger, *Georgia Public Service Commission*

Ms. S. W. Kernizan, *Georgia Public Service Commission*

Mr. K. C. Greene, *Troutman Sanders*

Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company
ND-19-0190
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3 and Unit 4
Completion Plan for Uncompleted ITAAC 2.3.14.04 [Index Number 480]**

ITAAC Statement

Design Commitment

4. Displays of the parameters identified in Table 2.3.14-1 can be retrieved in the MCR.

Inspections, Tests, Analyses

Inspection will be performed for retrievability of parameters in the MCR.

Acceptance Criteria

The displays identified in Table 2.3.14-1 can be retrieved in the MCR.

ITAAC Completion Description

An inspection is performed to verify the retrievability of the Vogtle Electric Generating Plant (VEGP) Unit 3 and Unit 4 plant parameters in the Main Control Room (MCR). The inspection for retrievability confirms that the displays of the parameters identified in COL Appendix C Table 2.3.14-1 (Attachment A) can be retrieved in the MCR.

The inspection is performed in accordance with the Unit 3 and Unit 4 component test package work orders (References 1 and 2, respectively) for Demineralized Water Transfer and Storage System (DWS) component indication verifications, and visually confirms that when each of the displays of parameters identified in Attachment A is summoned at an MCR workstation, the summoned plant parameter appears on a display monitor at that MCR workstation.

The Unit 3 and Unit 4 component test results (References 1 and 2, respectively) confirm that the VEGP Unit 3 and Unit 4 plant parameter displays listed in Attachment A can be retrieved in the MCR.

References 1 and 2 are available for NRC inspection as part of the Unit 3 and Unit 4 ITAAC 2.3.14.04 Completion Packages (References 3 and 4, respectively).

List of ITAAC Findings

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company performed a review of all ITAAC findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant findings associated with the ITAAC.

References (available for NRC inspection)

1. SNCXXXXXX, "DWS Parameters Displays in MCR – ITAAC:SV3-2.3.14.04"
2. SNCXXXXXX, "DWS Parameters Displays in MCR – ITAAC:SV4-2.3.14.04"
3. 2.3.14.04-U3-CP-Rev 0, ITAAC Completion Package
4. 2.3.14.04-U4-CP-Rev 0, ITAAC Completion Package
5. NEI 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52"

Attachment A

Excerpt from COL Appendix C Table 2.3.14-1

Table 2.3.14-1		
Equipment Name	Tag No.	Display
Condensate Storage Tank Water Level	DWS-006	Yes