



REGULATORY DOCKET FILE COPY

VIRGINIA ELECTRIC AND POWER COMPANY

RICHMOND, VIRGINIA 23261

February 7, 1978

12 01 01 0 959 000

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Serial No. 50-280/77-29
PO&M/DLB:das
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Dear Mr. O'Reilly:

This is in response to your letter of November 11, 1977, in reference to the inspection conducted at Surry Power Station on October 4-7, 1977 and reported in IE Inspection Report Nos. 50-280/77-29 and 50-281/77-29. This is a supplement to our previous responses of December 6, 1977 and December 21, 1977, and addresses Appendix A, page 2, item E of your letter of November 11, 1977.

In order to insure that the Liquid Waste Monitor is performing as specified in Technical Specification 3.7.E and Table 3.7-5 the following program will be conducted.

- (1) In order to insure that the liquid waste monitor will alarm and shut the discharge valve as required, a test will be done using liquid waste samples with isotope activities near the alarm set-point as determined by the multi-channel analyzer. The test will be conducted during the week of February 6, 1978.
- (2) In order to evaluate overall performance of the liquid waste monitor, a correlation study will be conducted between monitor readings, and liquid waste samples of known isotope activities. In order to obtain liquid waste samples from worst case conditions, the study will include samples from liquid waste due to the March Unit No. 2 shutdown. This study should be completed by April 15, 1978.

Very truly yours,

C. M. Stallings

C. M. Stallings
Vice President - Power Supply
and Production Operations

cc: Mr. Robert W. Reid ✓

780410012

A 001 / S *
op



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
230 PEACHTREE STREET, N.W. SUITE 818
ATLANTA, GEORGIA 30303
FEB 9 1978

Central File
50-280
281

In Reply Refer To:
RII:SCE
50-280/77-29
50-281/77-29

Virginia Electric and Power Company
ATTN: Mr. W. L. Proffitt
Senior Vice President, Power
P. O. Box 26666
Richmond, Virginia 23261

Gentlemen:

Thank you for your letter of February 7, 1978, informing us of steps you have taken to correct the items of noncompliance concerning activities under NRC Operating License Nos. DPR-32 and DPR-37 brought to your attention in our letter of November 11, 1977. We will examine your corrective actions and plans during subsequent inspections.

We appreciate your cooperation with us.

Sincerely,

J. T. Sutherland
J. T. Sutherland, Chief
Fuel Facility and Materials
Safety Branch

cc: Mr. T. L. Baucom
Surry Power Station
P. O. Box 315
Surry, Virginia 23883

WR

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 7, 1978

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Serial No. 519B/111177
PO&M/DLB:das
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Dear Mr. O'Reilly:

This is in response to your letter of November 11, 1977, in reference to the inspection conducted at Surry Power Station on October 4-7, 1977 and reported in IE Inspection Report Nos. 50-280/77-29 and 50-281/77-29. This is a supplement to our previous responses of December 6, 1977 and December 21, 1977, and addresses Appendix A, page 2, item E of your letter of November 11, 1977.

In order to insure that the Liquid Waste Monitor is performing as specified in Technical Specification 3.7.E and Table 3.7-5 the following program will be conducted.

- (1) In order to insure that the liquid waste monitor will alarm and shut the discharge valve as required, a test will be done using liquid waste samples with isotope activities near the alarm set-point as determined by the multi-channel analyzer. The test will be conducted during the week of February 6, 1978.
- (2) In order to evaluate overall performance of the liquid waste monitor, a correlation study will be conducted between monitor readings, and liquid waste samples of known isotope activities. In order to obtain liquid waste samples from worst case conditions, the study will include samples from liquid waste due to the March Unit No. 2 shutdown. This study should be completed by April 15, 1978.

Very truly yours,



C. M. Stallings
Vice President - Power Supply
and Production Operations

cc: Mr. Robert W. Reid