

APPENDIX C - STRUCTURAL DESIGN CRITERIATABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>
C.1	<u>CLASSIFICATION OF STRUCTURES</u>
C.1.1	General
C.1.2	Seismic Class I Structures and Systems
C.1.3	Seismic Class II Structures and Systems
C.2	<u>STRUCTURAL DESIGN BASIS</u>
C.2.1	Dead and Live Loads
C.2.2	Seismic Loads
C.2.3	Wind Loads
C.2.4	Tornado Loads
C.2.5	Special Loadings
C.2.5.1	Turbine Missiles
C.2.5.2	Tornado-Generated Missiles
C.2.5.3	Temperature Loads
C.2.5.4	Flood Loads and Flood Protection
C.2.6	Loading Combinations
C.2.6.1	Reactor Building and All Other Seismic Class I Structures
C.2.6.2	Reactor Vessel Pedestal
C.2.6.3	Spent Fuel Pool
C.2.6.4	Reactor Building 135' with Spent Fuel Storage Cask
C.2.7	Governing Codes and Regulations
C.2.7.1	Spent Fuel Pool Reevaluation
C.3	<u>ANALYSIS OF CLASS I STRUCTURES</u>
C.3.1	Scope
C.3.2	Structural Analysis
C.3.3	Seismic Analysis of Structures
C.4	<u>IMPLEMENTATION OF STRUCTURAL CRITERIA</u>
C.4.1	Reactor Building Floor System
C.4.2	Reactor Building Concrete Wall
C.4.3	Reactor Building Superstructure
C.4.4	Reactor Pedestal
C.4.5	Drywell Shielding Concrete
C.4.6	The Sacrificial Shield
C.4.7	Main Steam Pipe Chase
C.4.8	Spent Fuel Pool
C.4.9	Concrete Block Walls
C.4.10	Strength Tests and Crack Control for Concrete

TABLE OF CONTENTS (cont'd)

<u>SECTION</u>	<u>TITLE</u>
C.5	<u>COMPONENTS</u>
C.5.1	Intent and Scope
C.5.1.1	Components Designed by Rational Stress Analysis
C.5.1.2	Components Designed Primarily by Empirical Methods
C.5.1.3	Components Qualified for SQUG Methodology
C.5.2	Loading Conditions and Allowable Limits
C.5.2.1	Loading Conditions
C.5.2.1.1	Normal Conditions
C.5.2.1.2	Upset Conditions
C.5.2.1.3	Emergency Conditions
C.5.2.1.4	Faulted Conditions
C.5.2.2	Allowable Limits
C.5.3	Method of Analysis and Implementation of Criteria
C.5.3.1	Reactor Vessel
C.5.3.1.1	Vessel Fatigue Analysis
C.5.3.1.2	Vessel Seismic Analysis
C.5.3.2	Reactor Vessel Internals
C.5.3.2.1	Internals Deformation Analysis
C.5.3.2.2	Internals Fatigue Analysis
C.5.3.2.3	Internals Seismic Analysis
C.5.3.3	Piping
C.5.3.3.1	Piping Flexibility Analysis
C.5.3.3.2	Piping Seismic Analysis
C.5.3.3.3	Piping Mark I Load Analysis
C.5.3.4	Equipment
C.5.3.5	Cable Trays
C.5.3.6	Reactor Coolant System Supports
C.5.3.7	References

APPENDIX C - STRUCTURAL DESIGN CRITERIA

LIST OF TABLES

<u>TABLE</u>	<u>TITLE</u>
C.2.1	Damping Factors
C.2.2	Wind Loads
C.4.1	Reactor Building Floor System
C.4.2	Reactor Building Concrete Walls
C.4.3	Reactor Building Steel Superstructure
C.4.4	Reactor Concrete Pedestal
C.4.5	Drywell Shielding Concrete
C.5.1	Deformation Limit
C.5.2	Primary Stress Limit
C.5.3	Buckling Stability Limit
C.5.4	Fatigue Limit
C.5.5	Minimum Safety Factors
C.5.6	Reactor Vessel and Reactor Vessel Internals
C.5.7	Piping
C.5.8	Equipment
C.5.9	Damping Factors for Mark I Loads

APPENDIX C - STRUCTURAL DESIGN CRITERIA

LIST OF FIGURES

<u>FIGURE</u>	<u>TITLE</u>
C.2.1	Emergency Heat Sink Facility
C.3.1	Response Spectra (Design Earthquake)
C.3.2	Response Spectra (Maximum Credible Earthquake)
C.3.3	Reactor Building, Mathematical Model
C.3.3A	Primary Structure Model for 1997 Re-Analysis of Recirculation System Piping, RHR Piping, & RWC Piping Inside Primary Containment
C.3.4	Reactor Building, Design Earthquake, Maximum Moments
C.3.5	Reactor Building, Maximum Credible Earthquake, Maximum Moments
C.3.6	Reactor Building, Design Earthquake, Maximum Shear
C.3.7	Reactor Building, Maximum Credible Earthquake, Maximum Shear
C.3.8	Reactor Building, Design Earthquake, Maximum Displacements
C.3.9	Reactor Building, Maximum Credible Earthquake, Maximum Displacements
C.3.10	Reactor Building, Design Earthquake, Maximum Accelerations
C.3.11	Reactor Building, Maximum Credible Earthquake, Maximum Accelerations
C.3.12	Response Spectra, Design Earthquake - 5%g, 2% Damping
C.3.12A	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - N/S, 0.5% Damping, ZPA = 1.0g

PBAPS UFSAR

LIST OF FIGURES (cont'd)

<u>FIGURE</u>	<u>TITLE</u>
C.3.12B	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - N/S, 2.0% Damping, ZPA = 1.0g
C.3.12C	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - N/S, 7.0% Damping, ZPA = 1.0g
C.3.12D	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - E/W, 0.5% Damping, ZPA = 1.0g
C.3.12E	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - E/W, 2.0% Damping, ZPA = 1.0g
C.3.12F	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - E/W, 7.0% Damping, ZPA = 1.0g
C.3.12G	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - Vert, 0.5% Damping, ZPA = 1.0g
C.3.12H	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - Vert, 2.0% Damping, ZPA = 1.0g
C.3.12I	Regulatory Guide 1.60 Free-Field Response Spectra From Synthetic Acceleration Time History - Vert, 7.0% Damping, ZPA = 1.0g
C.3.12J	2% Damped Spectral Comparison between Target DE Response Spectrum and Spectrum from TAFT Time History (After Scaling)
C.3.12K	2% Damped Spectral Comparison between Target MCE Response Spectrum and Spectrum from TAFT Time History (After Scaling)
C.3.12L	5% Damped Spectral Comparison between Target MDC Response Spectrum and Spectrum from TAFT Time History (After Scaling)