

Hope Creek Safety Related UPS Replacement

Application of RIS 2002-22 Supplement 1 to implement
Digital UPS Systems Under 10CFR50.59

NRC Public Meeting
May 9, 2019

Agenda

- **Introduction**
- **Purpose of meeting**
- **Scope of Project**
- **Qualitative Assessment Overview**
- **System Architecture**
- **Failure Modes and Effects**
- **Design Attributes**
- **Quality of the Design Process**
- **Operating Experience**
- **Conclusion**

Purpose of Meeting

- Hope Creek plans to install Ametek NDPP Class 1E digital Uninterruptible Power Supply (UPS) systems under a 10 CFR 50.59 evaluation
- A qualitative assessment was prepared using the criteria described in Regulatory Information Summary (RIS) 2002-22 Supplement 1
- This meeting seeks to inform NRC staff of the results of the qualitative assessment
 - Application of RIS guidance
 - Technical approach to addressing design
 - Conclusion that the likelihood of failure is sufficiently low

Scope of Project

- **Hope Creek has 8 safety related UPS systems in four safety channels**
 - Two UPS systems per channel
 - One UPS for Bailey Logic system (Main Control Room Interface)
 - One UPS for Emergency Core Cooling System functions
 - Safety Function: Supply 120VAC power to downstream loads
- **All 8 systems will be replaced with Ametek NDPP UPS systems**
 - System replacement will be 1 channel (2 UPS's) per outage
 - First installation scheduled for Spring 2021


Qualitative Assessment Overview

- **Application of guidance under RIS 2002-22, Supplement 1**
- **Qualitative assessment & failure analysis of new design**
 - Review focused on digital elements of the new UPS
 - Develop application-specific Failure Modes and Effects Analysis (FMEA) for digital elements the UPS
 - Identification of design attributes that serve to prevent or limit failures
 - Assessment of software design development, life cycle and quality assurance
 - Factory visit and thread sample of design documents
 - Review of Operating Experience (OE) from non-safety installations
 - Assessment of nuclear design against non-nuclear industrial models provided by Ametek


System Architecture

- **Double-Conversion UPS System**
- **Three inputs – Normal 480 VAC, Bypass 480 VAC, Backup 125 VDC (Batteries)**
- **Single 120 VAC Output**
- **Major components**
 - Rectifier
 - Inverter
 - Static Switch
 - Regulating transformer (no digital content)
- **Normal 480 VAC feed transformed to 120 VAC then rectified to 125 VDC**
- **125 VDC is diode auctioneered with emergency 125 VDC from batteries**
- **125 VDC bus feeds inverter which converts to 120 VAC**
- **Upon loss of inverter - static transfer switch swaps to alternate 480 VAC feed via regulating transformer**

System Architecture



System Architecture



Failure Modes of New UPS Design

- **Single Random Hardware Failure**
 - Failure modes of the new digital UPS are bounded by failure analysis in the Hope Creek Updated Final Safety Analysis Report (UFSAR)
- **Loss of Power**
 - Effects of upstream power loss are identical to existing UPS
 - Does not cause a failure of the safety function
- **Systematic Failure of All UPS's Due to a Design Defect**
 - Evaluates postulated failure modes of each of the four controllers (Alarm, Rectifier, Display, Inverter)
 - Provides justification that failure modes have no effect on safety function, or are of sufficiently low likelihood
 - Determination of low likelihood based on design attributes, quality, and operating experience per Section 3 of RIS 2002-22 Supplement 1
 - Design attributes evaluated using supplemental guidance from EPRI 3002005326 – *Methods for Assuring Safety and Dependability when Applying Digital Instrumentation and Control Systems*

Failure Effects

- **Single Random Hardware Failure**
 - Failure effects evaluation assumes loss of 120VAC output
 - No change to failure effects described in the UFSAR
- **Systematic Failure Due to a Design Defect**
 - Common Cause Failure (CCF) likelihood determined to be sufficiently low per results of qualitative assessment
 - Worst case CCF requires unlikely sequence of events
 - Complete loss of UPS function from a CCF can only happen when the 4kV safety buses are de-energized
 - 13-second window during diesel start and load sequence after LOP
 - CCF coping ability assessed despite 'sufficiently low' conclusion
 - Loss of output evaluated concurrent with a LOP (during 13-second diesel start time)
 - Recoverable via manual starting of EDGs

Design Attributes

- **Internal diversity**
 - An analog circuit can force a transfer to bypass on a gross failure of the inverter
- **Limited concurrent triggers**
 - Loss of upstream AC on a Loss of Offsite Power is the only identified common trigger
- **Segmentation**
 - Internal communications provide functional segmentation between sub-systems
 - Safety function processor is isolated from internal communications – complies with DI&C ISG-04 staff position

Design Attributes

- **Self-test and diagnostics**
 - Diagnostics cover initialization data, runtime checks of program memory and RAM, and timeouts for data link activity
 - Redundant communications messages
 - Watchdog timer monitors completion of inverter control function code
- **Diverse indication of failure**
 - Independent transducers monitor battery voltage, output voltage and output current, and provide alarms in the main control room
- **Extensively tested safety function processor**
 - Single loop operating system w/ fixed interval interrupt routine
 - Invariant execution
 - Programmed in Assembly, during testing register values are inspected to ensure correct execution

Quality of the Design Process

- **Sargent & Lundy Review**
 - S&L, on behalf of PSEG, performed reviews of the Ametek software development processes
 - S&L concluded that Ametek has an effective V&V process
 - Review of phase summary and discrepancy reports showed effective identification and correction of issues
- **NRC Inspection Report 99901427/2017-201 [ML17135A403]**
 - Included a review of Ametek's software development lifecycle
 - Later phases were in draft status
 - Concluded lifecycle activities satisfied the regulatory requirements of Appendix B
 - No findings were identified for digital I&C design control

Operating Experience

- **Ametek has extensive industrial and non-1E nuclear operating history on the DPP line of products**
 - Ametek service database was reviewed
 - Hope Creek and Salem operating history of the DPP inverters was reviewed
- **Zero inverter failures identified that were attributed to a software defect**
- **Applicability to the NDPP**
 - NDPP is an evolutionary development from the DPP industrial product line
 - Removal of external digital communications and parallel output functions
 - Addition of runtime memory diagnostics and serial link redundant messaging

Conclusion

- **Conclusion is that the likelihood of systematic failure due to a design defect is sufficiently low**
 - Evaluated per the criteria from Section 3 of RIS 2002-22, Supplement 1
- **Supplemental guidance via preventive measures in EPRI 3002005326**
 - **Reduce the likelihood of a CCF caused by an operating system defect**
 - Table A33-P3 – Demonstrate that a defect will not be activated when the SSC is needed to perform its required function
 - Table A33-P1 – Minimize potential for concurrent activating conditions, demonstrate an activated defect is self-announcing, and reduce defect potential through documented software quality.
 - **Reduce the likelihood of a CCF caused by data communications**
 - Table A39-P4 – Reduce the likelihood of a communication interface design defect

Hope Creek Vital Bus Inverter Replacement

Questions?