

May 15, 2019

Title: Recurring Teleconference with Exelon Generating Company, LLC concerning the Subsequent License Renewal Application for Peach Bottom Atomic Power Station, Units 2 & 3

Date(s) and Time(s): June 19, 2019, 01:30 PM to 00:00 AM
June 26, 2019, 01:30 PM to 00:00 AM
July 03, 2019, 01:30 PM to 00:00 AM
July 10, 2019, 01:30 PM to 00:00 AM
July 17, 2019, 01:30 PM to 00:00 AM
July 24, 2019, 01:30 PM to 00:00 AM
July 31, 2019, 01:30 PM to 00:00 AM

Location: Teleconference

Category: This is a Category 1 meeting. The public is invited to observe this meeting and will have one or more opportunities to communicate with the NRC after the business portion of the meeting but before the meeting is adjourned.

Purpose: To discuss technical details, including, but not limited to, the licensee's response to Requests for Additional Information

Contact: Bennett Brady
301-415-2981
Bennett.Brady@nrc.gov

Teleconference:	<u>Bridge Number</u> (877) 934-9177	<u>Pass Code</u> 90301
-----------------	--	---------------------------

PUBLIC MEETING AGENDA

Recurring Teleconference with Exelon Generating Company, LLC concerning the Subsequent License Renewal Application for Peach Bottom Atomic Power Station, Units 2 & 3

June 19, 2019, 01:30 PM to 00:00 AM

June 26, 2019, 01:30 PM to 00:00 AM

July 03, 2019, 01:30 PM to 00:00 AM

July 10, 2019, 01:30 PM to 00:00 AM

July 17, 2019, 01:30 PM to 00:00 AM

July 24, 2019, 01:30 PM to 00:00 AM

July 31, 2019, 01:30 PM to 00:00 AM

Teleconference

Time***Topic******Speaker***

1. Internal Coatings/Lining AMP –

SLRA Table 3.3.2-13, “Emergency Service Water System,” states that stainless steel with internal coating is included within the scope of the program; however, SLRA Section B.2.1.29 does not include stainless steel.

2. Buried Pipe RAI B.2.1.28-1 Response –

1:30
pm

NRC Staff
and Licensee
Staff

- Response does not provide docketed confirmation that all other in-scope stainless steel (not covered under Enhancement No. 7) is coated in accordance with the “preventive actions” program element of GALL-SLR Report AMP XI.M41.
- The response states that one inspection of buried stainless steel piping will be performed in the 10-year period prior to the SPEO. GALL-SLR Report AMP XI.M41 recommends two inspections for a two-unit site.

Exelon Response
Opportunity for Public Comment

The meeting will conclude after the technical discussion is complete and the public has an opportunity to comment or at 3:30 p.m., whichever is earlier.

- NRC questions on projected 80-year fatigue for various locations
- Exelon response
- Questions or comments from the public

The time of the meeting is local to the jurisdiction where the meeting is being held.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If reasonable accommodation is needed to participate in this meeting, or if a meeting notice, transcript, or other information from this meeting is needed in another format (e.g., Braille, large print), please notify the NRC meeting contact. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

ADAMS Accession Number: ML19162A218

Name	EOesterle	BBrady	SLent	LGibson
Office	NRR/DMLR/BC	NRR/DMLR/PM	NRR/DMLR/LA	NRR/DMLR/PM
Date			05/15/2019	05/15/2019

OFFICIAL RECORD COPY

Link to meeting details: <https://www.nrc.gov/pmns/mtg?do=details&Code=20190534>