

NUREG/CR-6850 FIRE PRA METHODOLOGY

Module 1

**Internal Event, At-Power
Probabilistic
Risk Assessment Model for SNPP**

Task 5: Fire-Induced Risk Model Development

Nicholas Melly – Nuclear Regulatory
Commission

Fire PRA Workshop

June 24, 2019 – June 28, 2019

Rockville, MD U.S. NRC HQ



Fire PRA Risk Model

Purpose (per 6850/1011989)

- Purpose: Describe the procedure for developing the Fire PRA model to calculate CDF, CCDF, LERF, and CLERP for fire ignition events
- Fire Risk Model
 - Key input for Quantitative Screening (Task 7)
 - Used to quantify CDF/CCDF and LERF/CLERP
- Process is iterative to ensure appropriate agreement among fire PRA Component List, Fire PRA Model, cable identification, and quantitative screening

Fire PRA Risk Model

Corresponding PRA Standard Element

- Primary match is to element PRM - Equipment Selection
 - PRM Objectives (as stated in the PRA standard):

“(a) to identify the initiating events that can be caused by a fire event and develop a related accident sequence model. (b) to depict the logical relationships among equipment failures (both random and fire induced) and human failure events (HFEs) for CDF and LERF assessment when combined with the initiating event frequencies”

Fire PRA Risk Model

HLRs (per the PRA Standard)

- HLR-PRM-A: The Fire PRA shall include the Fire PRA plant response model capable of supporting the HLR requirements of FQ
- HLR-PRM-B: The Fire PRA plant response model shall include fire-induced initiating events, both fire induced and random failures of equipment, fire-specific as well as non–fire-related human failures associated with safe shutdown, accident progression events (e.g., containment failure modes), and the supporting probability data (including uncertainty) based on the SRs provided under this HLR that parallel, as appropriate, Part 2 of this Standard, for Internal Events PRA
- HLR-PRM-C: The Fire PRA shall document the Fire PRA plant response model in a manner that facilitates Fire PRA applications, upgrades, and peer review

Fire PRA Risk Model

Scope (per 6850/1011989)

- Task 5: Fire-Induced Risk Model Development
 - Constructing the PRA Model
 - Step 1—Develop the Fire PRA CDF/CCDP Model
 - Step 2—Develop the Fire PRA LERF/CLERP Model

Fire PRA Risk Model

General Comment/Observation

- Task 5 does not represent any changes from past practice, but what is modeled is largely based on Task 2 with HRA input from Task 12
- Bottom line – Just “tweaking” your Internal Events PRA is probably NOT sufficient

Task 5: Fire Risk Model Development

General Objectives

- Purpose: Configure the Internal Events PRA to provide fire risk metrics of interest (primarily CDF and LERF)
 - Based on standard state-of-the-art PRA practices
 - Intended to be applicable for any PRA methodology or software
 - Allows user to quantify CDF and LERF, or conditional metrics CCDF and CLERP
 - *Conceptually, nothing “new” here – Need to “build the PRA model” reflecting fire induced initiators, equipment and failure modes, and human actions of interest*

Task 5: Fire Risk Model Development

Inputs/Outputs

- Task inputs and outputs:
 - Inputs from other tasks: (Note: Inclusion of spatial information requires cable locations from Task 3)
 - Sequence considerations, initiating event considerations, and components from Task 2 (Fire PRA Component Selection)
 - Unscreened fire compartments from Task 4 (Qualitative Screening)
 - HRA events from Task 12 (Post-Fire HRA)
 - Output to Task 7 (Quantitative Screening) which will further modify the model development
 - Can always iterate back to refine aspects of the model

Task 5: Fire Risk Model Development

Steps in Procedure

- Two major steps:
 - Step 1: Develop CDF/CCDP model
 - Step 2: Develop LERF/CLERP model

Task 5: Fire Risk Model Development

Steps in Procedure/Details

- Step 1 (2): Develop CDF/CCDP (LERF/CLERP) models
- Step 1.1 (2.1): Select fire-induced initiators and sequences and incorporate into the model
 - Corresponding SRs: PRM-A1, A2, A3, B1-B15
 - Fire initiators are generally defined in terms of compartment fires or fire scenarios
 - Each fire initiator is mapped to one or more internal event initiators to mimic the fire-induced impact to the plant
 - Initiating events previously screened in the internal events analysis may have to be reconsidered for the Fire PRA
 - Final mapping of fire initiator to internal events initiators is based on cable routing information (Task 3)


Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)

- Step 1.1 (2.1) – (Cont.)
 - The structure of Internal Events PRA should be reviewed to determine proper mapping of fire initiators
 - The Internal Events PRA should have the capability to quantify CDF and LERF sequences
 - Internal events sequences form bulk of sequences for Fire PRA, but **a search for new sequences should be made** (see Task 2). Some new sequences may require new logic to be added to the PRA model
 - Plants that use fire emergency procedures (FEPs) may need special models to address unique fire-related actions (e.g., pre-defined fire response actions and MCR abandonment)
 - Some human actions may induce new sequences not covered in Internal Events PRA and can “fail” components
 - Example: SISBO, or partial SISBO

Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)



Example of new logic with a fire-induced loss of raw water initiating event



Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)

- Step 1.2 (2.2): Incorporate fire-induced equipment failures
 - Corresponding SRs: PRM-A4, B3, B6, B9
 - Fire PRA database documents list of potentially failed equipment for each fire compartment
 - Basic events for fire-induced spurious operations are defined and added to the PRA model (FAQ 08-0047)
 - Inclusion of spatial information requires equipment and cable locations
 - May be an integral part of model logic or handled with manipulation of a cable location database, etc.


Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)




Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)




Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)



Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)




Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)

- Step 1.3 (2.3): Incorporate fire-induced human failures
 - Corresponding SRs: PRM-B9, B11
 - New fire-specific HFEs may have to be added to the model to address actions specified in FEPs (Note: All HFEs will be set at screening values at first, using Task 12 guidance)
 - Successful operator actions may temporarily disable (“fail”) components

Task 5: Fire Risk Model Development


Steps in Procedure/Details (Cont.)



Task 5: Fire Risk Model Development

Steps in Procedure/Details (Cont.)

Suppose a proceduralized manual action
carried out for fires in compartments AA & BB
defeats Pump A operation by de-energizing the
pump (opening its breaker drawer)...



Sample Problem Exercise for Task 5

- Distribute blank handout for Task 5, Steps 1 and 2
- Distribute completed handout for Task 5, Steps 1 and 2
- Question and Answer Session

Mapping HLRs & SRs for the PRM Technical Element to NUREG/CR-6850, EPRI TR 1011989

Technical element	HLR	SR	6850/1011989 sections that cover SR	Comments
PRM	A	The Fire PRA shall include the Fire PRA plant response model capable of supporting the HLR requirements of FQ.		
		1	5.5.1.1, 5.5.2.1	
		2	5.5.1.1, 5.5.2.1	
		3	5.5.1.1, 5.5.2.1	
		4	5.5.1.1, 5.5.1.2, 5.5.2.1, 5.5.2.2	

Mapping HLRs & SRs for the PRM Technical Element to NUREG/CR-6850, EPRI TR 1011989

Technical element	HLR	SR	6850/1011989 sections that cover SR	Comments
PRM	B	The Fire PRA plant response model shall include fire-induced initiating events, both fire induced and random failures of equipment, fire-specific as well as non-fire-related human failures associated with safe shutdown, accident progression events (e.g., containment failure modes), and the supporting probability data (including uncertainty) based on the SRs provided under this HLR that parallel, as appropriate, Part 2 of this Standard, for Internal Events PRA.		
		1	5.5.1.1, 5.5.2.1	
		2	5.5.1.1, 5.5.2.1	
		3	5.5.1.1, 5.5.1.2, 5.5.2.1, 5.5.2.2	
		4	5.5.1.1, 5.5.2.1	
		5	5.5.1.1, 5.5.2.1	
		6	5.5.1.1, 5.5.1.2, 5.5.2.1, 5.5.2.2	
		7	5.5.1.1, 5.5.2.1	
		8	5.5.1.1, 5.5.2.1	
		9	5.5.1.1, 5.5.1.2, 5.5.1.3, 5.5.2.1, 5.5.2.2, 5.5.2.3	
		10	5.5.1.1, 5.5.2.1	
		11	5.5.1.1, 5.5.1.3, 5.5.2.1, 5.5.2.3	
		12	5.5.1.1, 5.5.2.1	
		13	5.5.1.1, 5.5.2.1	
		14	5.5.1.1, 5.5.2.1	
		15	5.5.1.1, 5.5.2.1	
		12	5.5.1.1, 5.5.2.1	
		13	5.5.1.1, 5.5.2.1	
		14	5.5.1.1, 5.5.2.1	
		15	5.5.1.1, 5.5.2.1	

Mapping HLRs & SRs for the PRM Technical Element to NUREG/CR-6850, EPRI TR 1011989

Technical element	HLR	SR	6850/1011989 sections that cover SR	Comments
	C	The Fire PRA shall document the Fire PRA plant response model in a manner that facilitates Fire PRA applications, upgrades, and peer review.		
		1	n/a	Documentation not covered in 6850/1011989