



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 22, 2019

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer
Exelon Nuclear
LaSalle County Station
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR
LICENSE AMENDMENT NOS. 237 AND 223 TO RENEWED FACILITY
OPERATING LICENSES RE: REMOVAL OF OPERATING MODE
RESTRICTIONS FOR PERFORMING SURVEILLANCE TESTING OF THE
DIVISION 3 BATTERY AND HIGH-PRESSURE CORE SPRAY DIESEL
GENERATOR (EPID L-2018-LLA-0162)

Dear Mr. Hanson:

By letter dated June 24, 2019 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML19121A505), the U.S. Nuclear Regulatory Commission (NRC) staff issued Amendment Nos. 237 and 223 to Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station (LSCS), Units 1 and 2, respectively. The amendments were in response to your application dated April 19, 2018, as supplemented by letters dated April 12, April 24, and May 23, 2019 (ADAMS Accession Nos. ML18157A123, ML19102A336, ML19114A420, and ML19144A168, respectively).

Due to an inadvertent error, the amendment issuance date on page 3 of the revised license pages for LSCS, Units 1 and 2, was missing. The corrected pages are enclosed with this letter and should replace the incorrect pages.

The correction does not change any of the conclusions in the safety evaluation associated with the amendments and does not affect the associated notice to the public.

B. Hanson

- 2 -

If you have any questions, please contact me at 301-415-3308 or via e-mail at Bhalchandra.Vaidya@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "B. Vaidya", with a horizontal line underneath.

Bhalchandra K. Vaidya, Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:
As stated

cc: Listserv

ENCLOSURE

LASALLE COUNTY STATION, UNITS 1 AND 2

REVISED LICENSE PAGES

DOCKET NOS. 50-373 AND 50-374

- (3) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- Am. 146
01/12/01 (4) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- Am. 202
07/21/11 (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2, and such Class B and Class C low-level radioactive waste as may be produced by the operation of Braidwood Station, Units 1 and 2, Byron Station, Units 1 and 2, and Clinton Power Station, Unit 1.

C. This renewed license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- Am. 198
09/16/10 (1) Maximum Power Level
- The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (3546 megawatts thermal).

- Am. 237
06/24/19 (2) Technical Specifications and Environmental Protection Plan
- The Technical Specifications contained in Appendix A, as revised through Amendment No. 237, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the renewed license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- Am. 194
08/28/09 (3) DELETED

- Am. 194
08/28/09 (4) DELETED

- Am. 194
08/28/09 (5) DELETED

- (2) Pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (3) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2, and such Class B and Class C low-level radioactive waste as may be produced by the operation of Braidwood Station, Units 1 and 2, Byron Station, Units 1 and 2, and Clinton Power Station, Unit 1.

Am. 189
07/21/11

C. This renewed license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

Am. 185
09/16/10

(1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (3546 megawatts thermal). Items in Attachment 1 shall be completed as specified. Attachment 1 is hereby incorporated into this license.

Am. 223
06/24/19

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 223, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the renewed license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR
LICENSE AMENDMENT NOS. 237 AND 223 TO RENEWED FACILITY
OPERATING LICENSES RE: REMOVAL OF OPERATING MODE
RESTRICTIONS FOR PERFORMING SURVEILLANCE TESTING OF THE
DIVISION 3 BATTERY AND HIGH-PRESSURE CORE SPRAY DIESEL
GENERATOR (EPID L-2018-LLA-0162) DATED JULY 22, 2019

DISTRIBUTION:

PUBLIC

PM File Copy

RidsACRS_MailCTR Resource

RidsNrrDorlLpl3 Resource

RidsNrrDssStsb Resource

RidsNrrLASRohrer Resource

RidsNrrPMLaSalle Resource

RidsRgn3MailCenter Resource

RidsNrrDeEeob Resource

PSnyder, NRR/DSS/STSB

KNguen, NRR/DE/EEOB

ADAMS Accession No.: ML19179A284

OFFICE	NRR/DORL/LPL3/PM	NRR/DORL/LPL3/LA	NRR/DORL/LPL3/BC(A)	NRR/DORL/LPL3/PM
NAME	BVaidya	SRohrer	LRegner	BVaidya
DATE	07/09/19	07/09/19	07/22/19	07/22/19

OFFICIAL RECORD COPY