

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	LICENSE TYPE					30	CAT 58				

CON'T

REPORT SOURCE 0 1 7 8

60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

DOCKET NUMBER 0 5 0 - 0 3 2 4 7 0 7 3 1 7 9 8 0 8 2 0 7 9 9

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Carolina Power & Light Company received notification from General Electric that an error

0 3 existed in the Technical Specifications (3.2.3.b) for the MCPR Limit from End-of-Cycle

0 4 (EOC) minus 2000 MWD/ST to EOC. This Technical Specification is not expected to be-

0 5 come applicable until approximately October 1979; consequently these limits have not

0 6 been exceeded. The old limits and new limits supplied by G.E. are as follows:

Fuel Type	Was	Should Be	Fuel Type	Was	Should Be	Fuel Type	Was	Should Be
7 X 7	1.21	1.22	8 X 8	1.27	1.29	8 X 8R	1.27	1.29

SYSTEM CODE R B (11)		CAUSE CODE B (12)		CAUSE SUBCODE A (13)		COMPONENT CODE F U E L X X (14)		COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
EVENT YEAR 7 9 (17)		SEQUENTIAL REPORT NO. 0 6 4 (18)		OCCURRENCE CODE 0 3 (19)		REPORT TYPE L (20)		REVISION NO. 0 (21)			
ACTION TAKEN G (22)		FUTURE ACTION G (23)		EFFECT ON PLANT Z (24)		SHUTDOWN METHOD Z (25)		HOURS 0 0 0 0 (26)		ATTACHMENT SUBMITTED N (27)	
NPRD-4 FORM SUB. N (28)		PRIME COMP. SUPPLIER N (29)		COMPONENT MANUFACTURER G 0 8 0 (30)							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 General Electric explained that the error was attributable to the use of incorrect

1 1 void coefficient data, and has identified action to prevent recurrence through inter-

1 2 nal procedures. A revision to Technical Specifications is being prepared to establish

1 3 the proper limits by EOC minus 2000 MWD/ST.

1	4											80
7	8											80
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				80
1	5	E	28	0	9	5	29	NA	D	31	Vendor Notification	32
7	8											80
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE				80
1	6	Z	33	Z	34	NA		NA				80
7	8											80
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION						80
1	7	0	0	0	37	Z	38	NA				80
7	8											80
PERSONNEL INJURIES		NUMBER		DESCRIPTION								80
1	8	0	0	0	40	NA	784330					80
7	8											80
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION								80
1	9	Z	42	NA								80
7	8											80
PUBLCITY ISSUED		DESCRIPTION										80
2	0	N	44	NA	7908230459							80
7	8											80
NRC USE ONLY												

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521