

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	B	V	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	26	LICENSE TYPE					30	57 CAT 58		

CON'T

REPORT SOURCE: 01 L 6 0 5 0 0 0 3 3 4 7 0 7 2 4 7 9 8 0 8 2 3 7 9 9

7 8 60 61 68 69 74 75 80

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0315 hours during performance of a surveillance test, the No. 1 Diesel Generator

0 3 | output breaker failed to close when the control switch was actuated. In addition, an

0 4 | alarm was received indicating a failure of the No. 1 Air Start Motors to start the

0 5 | Diesel Generator. The diesel started on the No. 2 air start motors. The No. 2

0 6 | Emergency Diesel Generator remained operable throughout the period.

07

0 8

7 8 9

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE		
7	8	E	E	X		Z		Z	Z	Z	Z	Z	Z	Z		Z		
		9	10	11	12	13		13	14	15	16	17	18	19	20	21		
17		EVENT YEAR				SEQUENTIAL REPORT NO.				OCCURRENCE CODE		REPORT TYPE		REVISION NO.				
LER/RO REPORT NUMBER		7	9	—		0	2	3	/		0	3	L	—		0		
		21	22	23		24	25	26	27	28	29	30	31	32				
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER				
X	X	Z		Z		0	0	0	0	N		Y		Z	Z	9	9	9
33	34	35		36		37	38	39	40	41		42		43	44	45	46	47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The air start motor failure resulted from a sticking pinion on the air motor. The
11 | pinion assembly was cleaned, exercised, and satisfactorily tested. The test circuit
12 | installed to monitor breaker control circuitry indicated the failure occurred in the
13 | manual start relays. Repeated cycling of these relays did not produce any failures.
14 | DLC Engineering is investigating the replacement of these relays.

7		8		9		FACILITY STATUS		% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION (32)		
1		5		G		(28)		0 0 0			(29)			N/A			B (31) Surveillance testing		
7		d		9				10			12			13			44		

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6
7 8 9 10 11

33 34

AMOUNT OF ACTIVITY (35)
N/A

LOCATION OF RELEASE (36)
N/A

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION (39)					
1	7	0	0	0	(37)	Z	(38)	N/A	

PERSONNEL INJURIES		80	
NUMBER	DESCRIPTION	41	
1 8	0 0 0	40	N/A

8 9		11 12		13 14		15 16		17 18		19 20	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		(43)					
1	3	Z	(42)			N/A		7908290472		853 322	

8 9 10
PUBLICITY
ISSUED DESCRIPTION (45) N/A
2 0 1 5 (44)
NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER J. A. Werling

PHONE: 412-643-1258