

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 8 1 5 7 9 8 0 9 1 1 7 9 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 While performing PT 3.1.14PC, Reactor Low Pressure Channel Calibration and Function

0 3 Test, B21-PS-N021D was found to be operating in an out of tolerance condition. The

0 4 allowable range for this instrument is 435 + 15 psig and it as-found condition was

0 5 395 psig.

0 6 Technical Specification 3.3.3, 6.9.1.9b

0 7

0 8

0 9

SYSTEM CCODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 19 VALVE SUBCODE 20

0 9 S F 11 X 12 Z 13 I N S T R U 14 Y 15 Z 16

17 LER/RO REPORT NUMBER 21 EVENT YEAR 22 SEQUENTIAL REPORT NO. 24 OCCURRENCE CODE 28 REPORT TYPE 30 REVISION NO. 32

0 9 7 9 23 0 7 4 27 0 3 29 L 31 0 32

ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 41 NPD-4 FORM SUB. 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44

0 9 E 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 Y 24 N 25 B 0 8 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 The instrument was recalibrated and returned to service. The instrument was out of

1 1 calibration due to instrument drift. Due to this instruments past reliability and

1 2 performance and because it is checked monthly, this is considered an isolated event

1 3 and no further action is required.

1 4

FACILITY STATUS 7 8 9 % POWER 10 OTHER STATUS 13 METHOD OF DISCOVERY 45 DISCOVERY DESCRIPTION 46

1 5 E 28 0 9 4 29 NA B 31 Periodic Test 32

ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

1 6 Z 33 Z 34 NA NA 36

PERSONNEL EXPOSURES 37 NUMBER 38 TYPE 39 DESCRIPTION 39

1 7 0 0 0 37 Z 38 NA 39

PERSONNEL INJURIES 40 NUMBER 41 DESCRIPTION 41

1 8 0 0 0 40 NA 41

LOSS OF OR DAMAGE TO FACILITY 42 TYPE 43 DESCRIPTION 43

1 9 Z 42 NA 43

PUBLICITY 44 ISSUED 45 DESCRIPTION 45

2 0 N 44 NA 45

7909130 456

NRC USE ONLY

68 69 80

917-926