

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE      NEW YORK, N. Y. 10019

(212) 397-6200



September 7, 1979  
JPN-79-56

Director of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito, Chief  
Operating Reactors Branch No. 3  
Division of Operating Reactors

Subject: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Adequacy of Station Electric Distribution  
System Voltage

---

Reference: Mr. W. Gammill letter to all reactor licensees,  
dated August 8, 1979

Dear Sir:

The referenced letter requested that the NRC be informed within 30 days if the Authority has previously completed the reviews of the concerns expressed in it. The Authority hereby refers the NRC staff to its previous letters to the NRC on this matter, as follows:

A - G. T. Berry letter to R. W. Reid dated October 18, 1976

This letter provided an answer to R. W. Reid letter to G. T. Berry dated August 12, 1976 and included, as attachment, our "Evaluation of Operability of Safety Related Equipment During a Degraded Voltage Condition" study, prepared specifically in response to Mr. Reid's concerns of August 12, 1976.

B - G. T. Berry letter to R. W. Reid dated July 13, 1977

This letter provided a preliminary response to R. W. Reid letter to G. T. Berry dated June 3, 1977 and included, as attachment, our "Degraded Voltage Protection for Emergency A-C Power System" study.

919 185

A015  
S/P

7909130502

C - G. T. Berry letter to R. W. Reid dated October 17, 1977


This letter completed the response to R. W. Reid letter of June 3, 1977 and included, as attachments, the following documents:

- a) "Modification to the Emergency A-C Power System Undervoltage Protection", which presented in detail our proposed manner to provide a second level of voltage protection to the emergency busses to mitigate the possible consequences of a sustained degraded voltage condition in these busses.
- b) "Proposed Changes to Technical Specifications - Degraded Voltage Protection for Emergency A-C Power System", prepared to comply with Position 3 of the enclosure to R. W. Reid letter of June 3, 1977, and
- c) "Technical Description and Discussion of Technical Specification Changes", supporting above modification.

Our records indicate that no answer from the NRC has yet been received and thus no efforts to implement the modification have been made.

It is the Authority's consideration that the three above listed letters with their attached documents and FSAR Sections 8.2 through 8.6 address all the concerns contained in W. Gammill letter of August 8, 1979, although not necessarily in the same order as expressed in the letter, and that, in consequence, no further action on our part is required on this matter.

Very truly yours,

  
Paul J. Early  
Assistant Chief Engineer-Projects