



# Nebraska Public Power District

P.O. BOX

CENTRAL FILES  
PDR:HQ  
LPDR  
TIC  
NSIC

CNSS790389

July 26, 1979

Mr. Karl W. Seyfrit, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region IV  
611 Ryan Plaza  
Suite 1000  
Arlington, Texas 76011

Subject: IE Bulletin 79-02

Reference: (1) NPPD Response to IE Bulletin 79-02 dated July 6, 1979  
(2) Telephone Conversation Between C. R. Noyes and  
J. Sutton of NRC on July 25, 1979

Dear Mr. Seyfrit:

As of this date, approximately 70% of the subject pipe base support plates using concrete expansion anchor bolts have been generically analyzed with respect to the parameters set forth in IE Bulletin 79-02. Seventy percent corresponds to 1100 base plates and of this group 4 base plates have a preliminary indication of having a safety factor of less than two. These base plates are currently being upgraded to achieve a safety factor of greater than five and have been assigned top priority with respect to work scheduling. A detailed review of the respective system operability associated with each of the four base plates has been completed and it has been determined that the system operability has not been compromised.

Sincerely,

L. C. Lessor  
Station Superintendent  
Cooper Nuclear Station

LCL:CRN:cg

POOR  
ORIGINAL

7909190521

979040