

7IC

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER • DALLAS, TEXAS 75201

TXX-3021

July 30, 1979

R. J. GARY

EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Washington, D. C. 20555

RIV

Docket No. 50-445/IE Bulletin 79-15
50-446/IE Bulletin 79-15

Attention: Director, Division of
Reactor Construction Inspection

COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
RESPONSE TO NRC
IE BULLETIN 79-15
FILE NO: 10115

Dear Sir:

In response to IE Bulletin No. 79-15, we offer the following:

Item 1 - CPSES has four deep draft pumps similar to those shown in Figures 1 and 2 utilized in safety-related applications.

Item 2 - The pump manufacturer is Hayward Tyler Company. The model designation is 24VSN vertical two stage. The capacity is 17,000 GPM (design) and 15,000 GPM (normal). Their application is the Station Service Water System for Units 1 and 2.

Item 3 - The overall length of the pumps is 45'9½" from the bellmouth flare to the top of the motor stool. The suction column has a 25" diameter and the impeller casing has a 36" diameter.

Item 4 - The pumps have not been installed as of this date.

Should you have any other questions, please advise.

Very truly yours,

R. J. Gary
R. J. Gary

RJG:dla

cc: Director, Region IV ✓

INCONSISTENT
ORIGINAL

969 337
7909200050