


ILLINOIS POWER COMPANY



U-0100
L08-79(07-26)-0

500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

Jul, 26, 1979

Mr. James G. Keppler
Director, Region III
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Clinton Power Station Units 1 & 2
Docket Nos. 50-461 and 50-462
Construction Permits No. CPPR-137 & CPPR-138

This is in reply to your letter of May 22, 1979, whereby you forwarded IE Bulletin No. 79-11 which reported on a problem encountered with faulty overcurrent trip devices in circuit breakers.

Please be advised that Westinghouse DB-75 and DB-50 circuit breakers will not be used with any safety related services at the Clinton Power Station.

Sincerely,

G. E. Wuller
Supervisor - Licensing
Generation Engineering Department

GEW/jh

cc: Director, Division of Reactor Operations Inspection
Office of Inspection & Enforcement, USNRC

1051 185

JUL 30 1979

7909280032