

DUKE POWER COMPANY

ATLANTA
POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

79 SEP 4 10:52

August 30, 1979

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

Mr. Harold D. Thornburg, Director
Division of Reactor Construction
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Re: McGuire Nuclear Station
50-369, 50-370
IE Bulletin 79-15

Dear Mr. Thornburg:

McGuire Nuclear Station does not utilize the "deep draft" type pumps referenced in the subject bulletin. All Core Spray and Residual Heat Removal Pumps at McGuire Nuclear Station are of the short-coupled design, where the pump impeller is mounted directly on the motor shaft.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr. *By WSB*

THH/sch

cc: Mr. J. P. O'Reilly
Director, Region II



1056 054

7909290 327