

P. O. BOX 33189

**DUKE POWER COMPANY**  
**GENERAL OFFICES**  
422 SOUTH CHURCH STREET  
**CHARLOTTE, N. C. 28242**

TELEPHONE: AREA 704  
373-4011

TIC  
50-491  
492  
493

19 JUL 19 19:06

July 9, 1979

Mr. J. P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Re: Cherokee Nuclear Station  
IE:II:JKR  
Inspection Reports: 50-491/78-8, 50-492/78-8,  
50-493/78-8  
Duke File: CK-1412.11-1

Dear Mr. O'Reilly:

Duke Power Company informed you on December 20, 1978, with respect to construction deficiency No. 491, 492, 493/78-08-03, a Halon fire protection system was on order and would be installed in the Cherokee Nuclear Station QA Vault. This system was installed and full compliance achieved on July 6, 1979.

Very truly yours,

*L. C. Dail*

L. C. Dail, Vice President  
Design Engineering Department

JDW/sr

7910050153

79011

1110 101

OFFICIAL COPY