

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L Q R P 3 0 0 - 0 0 0 0 0 - 0 0 4 1 1 1 1 4 - - 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

01 L 0 5 0 - 0 3 0 2 0 9 0 6 7 9 5 0 9 2 8 7 9 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0700 in Mode 5, it was determined that an individual had received an accumu-
03 lated whole body dose of 385 millirem. This exceeds the quarterly limit of
04 25% of 1250 millirem for first entry per 10 CFR 20.102. This created an
05 event reportable under 10 CFR 20.405. Redundancy NA. No effect upon the
06 plant or general public. This is the first occurrence of this type reported.
07
08
09

09 Z Z 11 X 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
17 LER NO REPORT NUMBER 7 9 0 8 4 0 3 L 0
21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED APPROX. ACHIEVED FIVE COMP. SUPPLIER COMPONENT MANUFACTURER
X 16 X 19 Z 20 Z 21 0 0 0 0 Y 22 N 23 Z 24 Z 9 9 9 9
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Adequate controls do not exist for reviewing revisions to the Code of Federal
11 Regulations and, subsequently, updating affected plant programs to assure
12 compliance.
13
14

15 G 23 0 0 0 29 NA 30 Notification from Nuclear Tech. Support
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
FACILITY STATUS POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
16 Z 33 Z 34 NA 35 LOCATION OF RELEASE 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
PUBLISHED DESCRIPTION 43 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
20 N 24 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
ISSUED DESCRIPTION

NAME OF PREPARER J. Cooper

PHONE (904) 795-6486

(SEE ATTACHED SUPPLEMENTARY INFORMATION SHEET)

1122-240

791000 276

SUPPLEMENTARY INFORMATION

Report No.: 50-302/79-084/03L-0

Facility: Crystal River Unit #3

Report Date: 28 September 1979

Occurrence Date: 6 September 1979

Identification of Occurrence:

Failure to comply with 10 CFR-20, Section .102, Determination of Prior Dose.

Conditions Prior to Occurrence:

Mode 5 cold shutdown.

Description of Occurrence:

At 0700 following a review of Radiation Exposure Records for compliance to a revision of 10 CFR-20.102, it was determined that an individual received an accumulated whole body dose of 385 millirem. This exceeds the limit of 25% of 1250 millirem specified in the revision for an individual without a signed statement of previous quarterly exposure.

Designation of Apparent Cause:

The cause of this event is attributed to a lack of adequate controls for reviewing revisions to the Code of Federal Regulations in the Federal Register and subsequently updating affected plant programs.

Analysis of Occurrence:

10 CFR-20.102, is designed to prevent an individual from exceeding the quarterly limit of 1.25 Rem. The total dose received by the individual .445 Rem which is within the allowed limit.

Corrective Action:

The plant Exposure Record Review Program has been revised to comply with the revision to 10 CFR-20.102.

Failure Data:

This is the first occurrence of this type reported.

/rc

1122 241