

**LICENSEE EVENT REPORT**

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

CON'T

REPORT SOURCE: 7 0 1 8  
DOCKET NUMBER: 60 61 0 5 0 0 0 3 1 8 68 69 70 9 2 2 7 9 74 75 80  
EVENT DATE: 70 9 2 2 7 9  
REPORT DATE: 75 1 0 0 9 7 9 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1515 the plant operator noticed that the plant computer had failed.

03 The computer was declared inoperable per T.S. 3.3.3.2. The excise

04 Nuclear instrumentation system remained operable during the event. The

05 | computer was returned to service at 1950. This has not been a repetitive

06 event.

0	7	
---	---	--

0	8
---	---

SYSTEM CODE I E 11		CAUSE CODE E 12		CAUSE SUBCODE G 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE X 15		VALVE SUBCODE Z 16							
EVENT YEAR 7 9 21 22		SEQUENTIAL REPORT NO. 0 3 5 24 25 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32									
ACTION TAKEN A 18 33		FUTURE ACTION Z 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 38 39 40		ATTACHMENT SUBMITTED N 23 41		NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER N 25 43		COMPONENT MANUFACTURER W 1 1 2 0 26 44 45 46 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Computer failure was due to a printed circuit board (Zerox No. WT 56)
---	---	---

failure which generated a RAD (Rapid Access Data) Storage disc "stop"

1 2 signal. This board and one additional board (Zerex No. WT 57) which

1 2 failed were replaced. Both boards are part of the RAD Motor Control

1 4 | Circuit. No preventive action is required.

FACILITY STATUS (28) 1 5 E 1 0 0 0 29 N/A 30 OTHER STATUS 31 A 32 DISCOVERY DESCRIPTION 33 Operator observation

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) N/A N/A

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION (39)						
1	7	0	0	0	(37)	Z	(38)	N/A		

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
0	0	0	40
		N/A	

8		9		11		12				
		LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		(43)		
1	9	Z	(42)	N/A						1178 248

2 9 10  
PUBLICITY  
ISSUED DESCRIPTION (45)  
2 0 N (44) N/A 7910180 383 NRC USE ONLY

NAME OF PREPARER S. M. Davis/P. G. Rizzo

PHONE: (301) 234-7942/7986

NRC USE ONLY

7910180.383