



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N.W., Suite 3100  
Atlanta, Georgia 30303

October 2, 1979

Attention: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Bechtel Job No. 9645  
File 0260/0498/15521  
Interim Report for PRD-79/12  
as Defined in 10 CFR 50.55 (e)  
AECM-79/110

On September 4, 1979, Mississippi Power & Light Company notified Mr. V. Brownlee of your office of a potentially reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns the Rosemount 510 DU Trip Units drawing more current than originally specified causing the power supplies to be inadequate. We have determined that this matter is reportable within the meaning of 10 CFR 50.55 (e). Details of the latest information are described in the attached report.

Yours truly,

L. F. Dale  
Nuclear Project Manager

JRF/JDR:mlc  
Attachment

cc: Mr. N. L. Stampley  
Mr. R. B. McGehee  
Mr. T. B. Conner

Mr. Victor Stello, Jr., Director  
Division of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

1173 346

7910190

Member Middle South Utilities System

OFFICIAL COPY

9 OCT 9 A10:33  
USNRC REGION II  
ATLANTA, GEORGIA