

E 8/3/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)  
DISTRIBUTION FOR INCOMING MATERIAL

50-289

REC: REID R W  
NRC

ORG: HERBEIN J G  
METROPOL EDISON

DOCDATE: 07/29/78  
DATE RCVD: 08/02/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED

SUBJECT:

LTR 1 ENCL 0

FURNISHING INFO CONCERNING FIRE PROTECTION AT SUBJECT FACILITY, PERTAINING TO  
UNLABELED FIRE DOORS.

PLANT NAME: THREE MILE ISLAND - UNIT 1

REVIEWER INITIAL: XJM  
DISTRIBUTOR INITIAL: M

\*\*\*\*\* DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS \*\*\*\*\*

FIRE PROTECTION INFORMATION (AFTER ISSUANCE OF OL).  
(DISTRIBUTION CODE A006)

FOR ACTION: BR CHIEF ORB#4 BC\*\*LTR ONLY(4)

INTERNAL:

REG FILE\*\*LTR ONLY(1)

I & E\*\*LTR ONLY(2)

AUXILIARY SYS BR\*\*LTR ONLY(2)

PLANT SYSTEMS BR\*\*LTR ONLY(5)

R. MURANKA\*\*LTR ONLY(1)

NRC PDR\*\*LTR ONLY(1)

OELD\*\*LTR ONLY(1)

AD FOR SYS & PROJ\*\*LTR ONLY(1)

WAMBACH\*\*LTR ONLY(1)

HANAUER\*\*LTR ONLY(1)

EXTERNAL:

LPDR'S

HARRISBURG, PA\*\*LTR ONLY(1)

TERA\*\*LTR ONLY(1)

NSIC\*\*LTR ONLY(1)

ACRS CAT B\*\*LTR ONLY(16)

*TTW. hpl.*

1489 130

DISTRIBUTION: LTR 39 ENCL 0  
SIZE: 1P

CONTROL NBR: 782150094

\*\*\*\*\* THE END \*\*\*\*\*

7910240

822 pcp



METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

July 28, 1978  
GQL 1294

Director of Nuclear Reactor Regulations  
Attn: R. W. Reid, Chief  
Operating Reactors Branch No. 4  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Fire Protection

In accordance with our letter of June 12, 1978 (GQL 1068), specifically, POSITION P13 - UNLABELED FIRE DOORS, a study has been initiated to determine which alternative (i.e., replacement, establishing adequacy through tests, or certification by a registered independent fire protection engineer) will be pursued such that the fire rating of all unlabeled fire doors can be established, and corrective action, if any, can be accomplished. It is anticipated that the study will be completed by September 15, 1978. The NRC will be advised upon completion of the study.

Per our letter of July 20, 1978 (GQL 1250), all unlabeled fire doors and frames will be replaced by fire door assemblies having an appropriate rating, or the adequacy of the fire resistance of the door assemblies will be established through tests, or other acceptable means.

Sincerely,

  
J. G. Herbein  
Vice President-Generation

JGH:RJS:cjg

782150094

1489 131

Aug 6  
1/10