

50-289

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO: Mr. Reid

FROM: Metropolitan Edison Co.
Reading, Pa.
R. C. Arnold

DATE OF DOCUMENT

DATE RECEIVED

3-10-76

☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

one signed

DESCRIPTION

ENCLOSURE

Letter reporting an incident with regard to the fact that there is no documentation supporting the seismic qualification of valves IC-V2, IC-V3, IC-V4 & IC-V5.....
(EVENT RPT 76-13/32)

POOR ORIGINAL

PLANT NAME:

Three Mile Island #1

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

SAFETY

FOR ACTION/INFORMATION

ENVIRO

3-10-76

JHR

BRANCH CHIEF:

Reid

W/3 CYS FOR ACTION

LIC. ASST:

Ingram

W/1 CYS

ACRS 16 CYS HOLDING/SENT TO LA Ingram

INTERNAL DISTRIBUTION

REC FILE

NRC PDR

I & E (2)

MIPC (3)

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES/SCHWENGER

CASE

F. WILLIAMS

FANAUER

TEDESCO/MACGARY

EISENHUT

BAER

SHAO

VOLLER/BUNCH

KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

LPDR: Harrisburg, Pa

TIC

NSYC

CONTROL NUMBER

1490 033

7910240 862 4446



METROPOLITAN EDISON COMPANY

SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

April 30, 1976
GQL 0647



Director of Nuclear Reactor Regulation
ATTN. R. W. Reid, Director
Branch No. 4
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. J. P. O'Reilly
Office of Inspection & Enforcement, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sirs:

Three Mile Island Nuclear Station Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Event Report 76-15/3L

The purpose of this event report is to inform you of a situation which may or may not prove to require reporting in accordance with TMI-1 Technical Specification 6.9.2.B.(1). Further, please note that we anticipate being able to supply a complete report regarding this situation by May 15, 1976.

Description of Event

It was recently discovered that no documentation supporting the seismic qualification of valves IC-V2, IC-V3, IC-V4 and IC-V6 in the intermediate cooling system could be found. Since these valves provide containment penetration isolation, we believe that the intent of the TMI-1 FSAR requires them to be Seismic Category 1.

Designation of Apparent Cause of Event

The apparent cause is still under investigation and will be reported in more detail in the above-referenced follow-up report.

4
all

3


1116

1490 034

Corrective Action

Efforts are still in progress to determine whether or not the subject valves are seismically qualified. The results of these efforts and any other pertinent related efforts will be reported in more detail in the follow-up report.

Sincerely,



R. C. Arnold
Vice President

RCA:JJM:ilm

1490 035