



METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 480 MIDDLETOWN, PENNSYLVANIA 17057

TELEPHONE 717-944-4041

Reg. Files

12 February 1976

Mr. J. P. O'Reilly
Directorate of Regulatory Operations
Region I
631 Park Avenue
King Of Prussia, Penna. 19406

POOR ORIGINAL

Operating License DPR-50
Docket 50-289

SUBJECT: Reportable Occurrence No. AO 76-7/1P

Dear Mr. O'Reilly:

This telegram is to confirm the telecon between Mr. Lee Spessard (Region I-NRC) and Mr. J. J. Colitz (TMI-1, Superintendent) at 1500 hours on 12 February 1976.

The following report is submitted in accordance with Paragraph 6.7.2.a.4 (Page 6-11) of the Technical Specifications.

During routine surveillance of snubbers in the Auxiliary Building, the snubber at location DHH-198 was found with an empty fluid reservoir. It was removed and replaced with an operable unit. The original snubber was tested, failed to lock properly and was declared inoperable.

The reservoir leakage appeared to be due to a damaged seal.

DHH-198 is located on the suction line to DH-P-13.

Very truly yours,

J. J. Colitz

J. J. Colitz
Unit 1 Superintendent
Three Mile Island Nuclear Station

JJC/pas

1490 066

7910240

875