

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO:

R. W. REID

FROM:

METROPOLITAN EDISON COMPANY
READING, PA.
R. C. ARNOLD

DATE OF DOCUMENT

5/26/76

DATE RECEIVED

5/28/76

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL☒ UNCLASSIFIED☐ COPY

NOE SIGNED

DESCRIPTION

LICENSEE EVENT REPORT (RO 50-289/76-17/990)
ON 5/13/76 CONCERNING AN INADEQUATELY
SUPPORTED CHEMICAL CLEANING SYSTEM PIPING
ASSOCIATED WITH REACTOR BUILDING PENETRATION
NO. 105.

ENCLOSURE

PLANT NAME:

THREE MILE ISLAND #1

(1-P)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

SAFETY

FOR ACTION/INFORMATION

ENVIRO

6/1/76

RJL

☒ BRANCH CHIEF: REID

W/3 CYS FOR ACTION

☒ LIC. ASST:

W/1 CYS

INGRAM

ACRS 16 CYS HOLDING/SENT TO LA

INTERNAL DISTRIBUTION

☒ REG FILE
☒ NRC FOR
☒ I & E (2)
☒ MIPC (3)
☒ SCHROEDER/IPPOLITO
☒ HOUSTON
☒ NOVAK/CHECK
☒ GRIMES/SCHWENGER (1) SA
☒ CASE
☒ E. HILLMAN
☒ HANAUER
☒ TEDESCO/MACCARY
☒ EISENHUT
☒ BAER
☒ SHAO
☒ VOLLMER/BUNCH
☒ KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

☒ LIDR: HARRISBURG, PA.
☒ TIC
☒ NSIC

CONTROL NUMBER

5368

7910240

1490 101

50-289

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO: Mr Reid

FROM: Metropolitan Edison Co
Reading, Pa
R C Arnold

DATE OF DOCUMENT

5-26-76

DATE RECEIVED

6-7-76

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL
☐ COPY☒ UNCLASSIFIED

one signed

DESCRIPTION

Ltr furnishing info concerning an incident which was inadvertently considered a reportable occurrence on 5-13-76..... and classified as ER 76-17/990.....

ENCLOSURE

PLANT NAME: Three Mile Island #1

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

--- SAFETY

FOR ACTION/INFORMATION

ENVIRO

6-7-76

enf

BRANCH CHIEF:

Reid

W/S CYS FOR ACTION

LIC. ASST:

Ingram

W/I CYS

ACRS 16 CYS HOLDING/SENT TO LA

INTERNAL DISTRIBUTION

REG FILE

NRC PDR

I & E (2)

MIPC (3)

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES/SCHWENCER

CASE

F. WILLIAMS

HANAUER

TEDESCO/MACCARY

EISENHUT

BAER

SHAO

VOLLMER/BUNCH

KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Hamburg, Pa

TIC

NSIC

5728

1490 102



METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

GQL 0778
May 26, 1976

Director of Nuclear Reactor Regulation
Attention R. W. Reid, Chief
Branch No. 4
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. J. P. O'Reilly
Office of Inspection & Enforcement, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406



Gentlemen:

Three Mile Island Nuclear Station Unit 1 (TMI-1)
Docket No. 50-289
Operating License No. DPR-50
Event Report ER 76-17/990


On May 13, 1976, Mr. J. J. Colitz (TMI-1 Unit Superintendent) informed Mr. Lee Spessard (Region I, NRC) of a situation which we felt may have been reportable in accordance with Technical Specification 6.9.2.A.(9).


It was suspected that the Chemical Cleaning System piping associated with Reactor Building Penetration No. 105 was inadequately supported and could subject that penetration to excessive stresses during a seismic event.

Seismic and deadload analyses performed by Gilbert Associates, Inc. have shown that stress values would be well within the code allowables and that no additional supports would be necessary.

This situation, therefore was not reportable.

Sincerely,


R. C. Arnold
Vice President



RCA:JJM:ilm

5728

1490 103