



METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 480 MIDDLETOWN, PENNSYLVANIA 17057

TELEPHONE 717-944-4041

July 3, 1975

Mr. J.P. O'Reilly, Director
Directorate of Regulatory Operations
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Operating License DPR-50
Docket 50-289

Subject: Environmental Incident No. EI 75-04

Dear Mr. O'Reilly:

This telegram is to confirm the telecon between Lee Spessard (Region I-NRC), and J.J. Colitz (Superintendent-Unit One) at 1500 hours, 3 July 1975.

Violation of the Environmental Technical Specification 2.2.2 (Page 10) in that the Plant River Water Discharge Suspended Solids exceeded the limit of 560 ppm maximum on 6 June 1975, during release of a waste neutralizing tank.

Analysis of the Suspended Solids in the Plant River Water Discharge on 6 June 1975 was 584 ppm.

Suspended solids analysis on the waste neutralizing tank water prior to release was only 5 ppm and suspended solids analysis of the river influent was 659 ppm during the release.

No immediate corrective action is in order. A change to the Environmental Technical Specifications to cover abnormal river water conditions will be evaluated.

Very truly yours,

J.J. Colitz
J.J. Colitz

Superintendent-Unit One
TMI Nuclear Station

JJC/db

1476 147
7910240 897