

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME		LICENSE NUMBER		LICENSE TYPE		EVENT TYPE	
01	P A T M I L	00-000000-00	7	1	1	04	
7	8	9	14	15	25	26	30
CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER		EVENT DATE	
01	CONT	7	L	050-0289	03	19	77
7	8	57	58	59	60	61	68
EVENT DESCRIPTION		REPORT DATE					
7	8	57	58	59	60	61	68

02	During Reactor cooldown conditions the discharge temperature						
03	changed by more than 2°F during any one hour. Previous						
04	occurrences of this type were 74-1, 74-8, 75-7, 75-8, 75-9. The						
05	total river water flow was increased and the primary plant cooldown						
06	rate were decreased to maintain the AT within the limits						
7	8	9	14	15	25	26	30

SYSTEM CODE		CAUSE CODE		COMPONENT CODE		PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER		VIOLATION	
07	C F	E	Z	Z	Z	Z	Z	Z	Z	Z	N
7	8	9	10	11	12	13	14	15	16	17	18

CAUSE DESCRIPTION											
08	Two valves would not respond to small demand open/close signals.										
09	One MDCT fan would not operate. The fan is scheduled for repair.										
10	The valves shall be inspected & repaired as necessary										
7	8	9	10	11	12	13	14	15	16	17	18

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
11	D	0	0	0	NA	A		NA			
7	8	9	10	11	12	13	14	15	16	17	18
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
12	Z	0			NA	NA					
7	8	9	10	11	12	13	14	15	16	17	18

PERSONNEL EXPOSURES												
NUMBER		TYPE		DESCRIPTION								
13	0	0	0	Z	NA							
7	8	9	10	11	12	13	14	15	16	17	18	

PERSONNEL INJURIES												
NUMBER		DESCRIPTION										
14	0	0	0	NA								
7	8	9	10	11	12	13	14	15	16	17	18	

OFFSITE CONSEQUENCES											
15	NA										
7	8	9	10	11	12	13	14	15	16	17	18

LOSS OR DAMAGE TO FACILITY											
TYPE		DESCRIPTION									
16	Z	NA									
7	8	9	10	11	12	13	14	15	16	17	18

PUBLICITY											
17	Included in regular weekly news release										
7	8	9	10	11	12	13	14	15	16	17	18

ADDITIONAL FACTORS											
18											
7	8	9	10	11	12	13	14	15	16	17	18

19											
7	8	9	10	11	12	13	14	15	16	17	18

NAME: W. E. Potts PHONE: 929-3601-(ext. 114)

7910250 **559**