

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER & LIGHT COMPANY

AND

PENNSYLVANIA ELECTRIC COMPANY
THREE MILE ISLAND NUCLEAR STATION UNIT 1

Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request No.

This Technical Specification Change Request is submitted in support of Licensee's request to change Appendix A to Operating License No. DPR-50 for Three Mile Island Nuclear Station Unit 1. As a part of this request, proposed replacement pages for Appendix A are also included.

METROPOLITAN EDISON COMPANY

By
Vice President-Generation

Sworn and subscribed to me this 9th day of January, 1976

My Commission Expires 12, 1979

Notary Public

1491 173

7910300 543

Metropolitan Edison Co. (Met-Ed)
Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289

Technical Specification Change Request No. 29

The licensee requests that the attached figures replace figures 3.5-2B and 3.5-2C of the existing Technical Specifications.

Reason for Proposed Change

At the time that figures 3.5-2B and 2C were produced, it was not recognized that specifying 440 EFPD in note 2 would result in any operating inconvenience. However, in order to implement figure 3.5-2C at 440 EFPD, a power reduction is necessary and this could be required at an inappropriate time such as during peak load. Therefore, to permit an orderly transition (during a non peak situation such as a weekend) to operation under figure 3.5-2C, note (2) should be changed to clarify that this transition is made at 440 ± 10 EFPD.

Safety Analysis Justifying Change

The analysis performed to develop figures 3.5-2B and 2C provided for a 440 ± 10 EFPD transition between the two figures, therefore, this change only clarifies that ± 10 EFPD is allowed for transition to operation under figure 3.5-2C.

Since this change only involves a clarification of existing specifications, this change does not represent a threat to the health and safety of the public.

1491 174



UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF

DOCKET NO. 50-289
OPERATING LICENSE NO. DPR-50

METROPOLITAN EDISON COMPANY

This is to certify that a copy of Technical Specification Change Request No. 29 to Appendix A of the Operating License for Three Mile Island Nuclear Station, Unit 1, dated January 9, 1976, and filed with the U.S. Nuclear Regulatory Commission January 9, 1976, has this 9th day January, 1976, been served on the chief executives of Londonderry Township, Dauphin County, Pennsylvania, and of Dauphin County, Pennsylvania, by deposit in the United States Mail, addressed as follows:

Mr. Weldon B. Arehart, Chairman
Board of Supervisors of
Londonderry Township
R.D. #1, Geyers Church Road
Middletown, Pennsylvania 17057

Mr. Charles P. Hoy, Chairman
Board of County Commissioners of
Dauphin County
Dauphin County Courthouse
Harrisburg, Pennsylvania 17120

METROPOLITAN EDISON COMPANY

By *R. Arnold*
Vice President-Generation

1491 175