

Metropolitan Edison Company
Reading Pa.
(R. E. Naidig)

TO: Dr. Peter A. Morris

CLASSIF. **U** POST OFFICE
REG. NO.

DESCRIPTION: (Must Be Unclassified)

Ltr req Amend to Prov Const Permit CFPB-40
to provide for the use of 170 wire
BHV post tensioning tendons in the
reactor containment bldg to replace
ENCLOSURES 90 wire BHV tendons.....

ACKNOWLEDGED

REMARKS: DISTRIBUTION: 1-formal file
1-supp'l file 1-AEC PER
2-Compliance 1-OCC
3-Hearing file 18-ACRS

DATE OF DOCUMENT:
July 10, 1968

DATE RECEIVED
July 12, 1968

NO. 2492

LTR. MEMO. REPORT. OTHER:

X

ORIG. CC: OTHER:

3 Notarized

20 conf'd cys rec'd

ACTION NECESSARY ☐

CONCURRENCE ☐

DATE ANSWERED:

NO ACTION NECESSARY ☐

COMMENT ☐

BY:

FILE CODE:

50-289

I.P.

REFERRED TO

DATE

RECEIVED BY

DATE

Long 7-12
w/8 cys for ACTION

Info Copies to:

H. Price & Staff

Dr. Morris/Schroeder

Boyd

Dube/Lovins

Rosen

Moore

Sevelli

DeYoung (2 cys)

Shovholt/Kelly

Do Not Remove

2492

U. S. ATOMIC ENERGY COMMISSION

MAIL CONTROL FORM

FORM AEC-326S
(8-60)

☆ U. S. GOVERNMENT PRINTING OFFICE: 1967-279-083

POOR ORIGINAL

1491 183

7910800 544

A



Metropolitan Edison Company

P. O. Box 542
READING, PENNSYLVANIA 19603

July 10, 1968

Dr. Peter A. Morris, Director
Division of Reactor Licensing
U. S. Atomic Energy Commission
Washington, D. C.

Dear Dr. Morris:

Subject: Three Mile Island Nuclear Station
Unit No. 1
Docket No. 50-289
Amendment No. 11
Provisional Construction Permit
No. CPPR-40

Ref. (a) Metropolitan Edison Company Letter to Dr. Peter A. Morris
of July 1, 1968

Reference (a) forwarded Amendment No. 11 to the Construction Permit
Application for the Three Mile Island Nuclear Station Unit No. 1; this
letter supplements Reference (a).

Metropolitan Edison Company hereby requests an amendment to the Provi-
sional Construction Permit No. CPPR-40 issued to Met-Ed for construction
of the Three Mile Island Nuclear Station. This amendment would provide
for the use of 170 wire BBRV post tensioning tendons in the reactor
containment building which would replace the 90 wire BBRV tendons pre-
viously described in Supplement No. 1 of the Preliminary Safety Analysis
Report.

Met-Ed is proceeding as follows: Construction of the reactor building
base mat will be in accordance with that described in the amended
Preliminary Safety Analysis Report, as amended through Amendment No. 10,



1491 184

Dr. Peter A. Morris

- 2 -

July 10, 1968

modified by the Met-Ed letter to Dr. Peter A. Morris of May 28, 1968, on the Reactor Containment Building Prestressing System. Design of the balance of the structure will be in accordance with Amendment 11 to the P.S.A.R. forwarded by Reference (a), subject to AEC approval.

Very truly yours,

R. E. Neidig
R. E. Neidig
Vice President

Sworn to and subscribed before me this 10th day of July, 1968.

Martin A. Koh

Notary Public for the State of Illinois

1491 185

