

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO:  
Mr. R. W. ReidFROM:  
Metropolitan Edison Company  
Reading, Pa.  
J. G. HerbeinDATE OF DOCUMENT  
10/6/77DATE RECEIVED  
10/13/77☐ LETTER  
☐ ORIGINAL  
☐ COPY☐ NOTORIZED  
☐ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
One Signed

## DESCRIPTION

Consists of info re Reactor Vessel  
Supports Adequacy.....PLANT NAME: Three Mile Island Unit No. 1  
RJL 10/13/77 (3-P)DISTRIBUTION FOR REACTOR VESSEL SUPPORT INFO  
FOR OPERATING REACTORS PER MR. TRAMMELL 7-12-76

## ENCLOSURE

## SAFETY

## FOR ACTION/INFORMATION

ASSIGNED AD:  
BRANCH CHIEF:  
PROJECT MANAGER:  
LIC. ASST:

Reid (7)

## INTERNAL DISTRIBUTION

☒ REG FILE  
NRC PDR  
BOSNAK  
ROSZTOCZY  
CHECK  
C. TRAMMELL  
SHAO  
P. BARANOWSKY  
P. NORIAN  
R. BOSNAK  
V. NOONAN

## EXTERNAL DISTRIBUTION

LPDR: Harrisburg, Pa

## CONTROL NUMBER



## METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

October 6, 1977  
GQL 1366

Director of Nuclear Reactor Regulation  
Attn: Mr. R. W. Reid, Chief  
Operating Reactors, Branch No. 4  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Sir:

Three Mile Island Nuclear Station Unit 1 (TMI-1)  
Operating License DPR-50  
Docket No. 50-289  
Reactor Vessel Supports Adequacy

### References:

1. Letter from R. W. Reid to R. C. Arnold, dated October 15, 1975
2. Letter from R. C. Arnold to R. W. Reid, GQL 1739, dated November 21, 1975
3. Letter from R. W. Reid to R. C. Arnold, dated June 9, 1976
4. Letter from R. C. Arnold to R. W. Reid, GQL 1189, dated August 20, 1976
5. An Analysis of the Probability of Pipe Rupture at Various Locations in the Primary Coolant Loop of a Babcock and Wilcox 177 Fuel Assembly Pressurized Water Reactor - Including the Effects of a Periodic Inspection, SAI-050-77-PA, September 1976
6. An Analysis of the Relative Probability of Pipe Rupture at Various Locations in the Primary Cooling Loop of a Pressurized Water Reactor Including the Effects of a Periodic Inspection, SAI 001-PA, June 1976

References 1 through 5 present the chronology of regulatory requests and response regarding the adequacy of reactor vessel supports assuming an instantaneous double-ended guillotine break inside the reactor cavity. Our last letter to you (Ref. 4) indicated participation of Metropolitan Edison Company in an Owner's Group that is investigating this problem. In August 1976, this Group discussed the analytical options with a broad spectrum of consultants. Our conclusion at that time was, that, given the disparity of opinion between the NRC staff, ACRS, and the analytical consultants regarding

1492 050

7719-00113

the appropriateness of the analytical tools, we would defer further analysis of the event until the appropriateness of the available analytical tools are demonstrated.

Instead, we propose for existing plants, such as TMI-1, to determine if such an event is likely enough to represent a risk to the health and safety of the public. We believe that it is possible to perform a quantitative study to determine if indeed the event was probable enough to require further analysis.

If the probability of the event is determined to be acceptably low, then further analysis is not warranted. The results of our quantitative analysis have been submitted as a Topical Report by Science Applications, Inc. (Ref. 5).

The report uses similar methodology as a report submitted by the Combustion Engineers User's Group (Ref. 6), but has taken advantage of experience gained in preparation of that report and expands the depth of analysis. The principal features that have been added to the 177 FA report are:

1. Considering the critical length of through wall defects to vary with the maximum stress level, rather than using a constant conservatively estimated lower bound value.
2. Considering the material properties, stress levels, and parameters in the detection probabilities and initial defect size distribution to be statistically fixed. Monte Carlo calculations of the distribution of the failure rates then allowed the degree of conservatism of the results to be quantitatively estimated.
3. Refinements in the analysis of the effects of in-service inspection on the failure probabilities allowed more accurate treatment of the effects of ISI.
4. Addition of further data to the base of the report.
5. Factoring in of the effect of ultrasonic inspection on rupture probabilities.

By this letter, we are providing our endorsement of the SAI Report and its conclusions. We believe that it fully satisfies your request for information concerning the adequacy of Reactor Vessel Supports.

We believe our design and operation of TMI-1, consistent with the SAI Report, provides sufficient assurance that there is no undue risk to public health

1492 051


• Mr. R. W. Reid

-3-

October 6, 1977  
GQL 1366

and safety and consider this matter to be adequately resolved. We are interested in discussing the salient features of this report with you at your earliest convenience.

Very truly yours,

A handwritten signature in dark ink, appearing to read "J. G. Herbein". The signature is fluid and cursive, with a large loop at the end of the last name.

J. G. Herbein  
Vice President

JGH:JRS:dkf

1492 052