

PERMITTEE

Permit Number PA 0009920

Metropolitan Edison Company

Amendment Number 2

Three Mile Island Generating Station

Page 1 of 1

NATIONAL POLLUTANT DISCHARGE  
ELIMINATION SYSTEM  
DISCHARGE PERMIT  
AMENDMENT NO. 2

Pursuant to the provisions of the Federal Water Pollution Control Act Amendments of 1972, the U.S. Environmental Protection Agency authorizes the following revisions to the above captioned permit:

I. Page 17a of 18 (Special Conditions)

- a. Add the following requirement to the permit as Special Condition 11:

The discharge of corrosion inhibitors, biocides (other than chlorine) and/or dispersants, without the prior written approval of the Regional Administrator, is prohibited.

The changes as set forth by this amendment and/were effective July 7 1977.

The remainder of the permit remains in full force and effect.

POOR ORIGINAL

By *Robert J. Whelan*  
Enforcement Division Director

July 7, 1977

Date

1490 171

7910810 491

9. It is recognized that influent quality changes, equipment malfunction, or other circumstances beyond the control of the permittee, may sometimes result in effluents exceeding the permit limitations despite the exercise of appropriate care, maintenance, and corrective measures by the permittee. The permittee ~~may come forward to demonstrate to the Agency~~ that such circumstances exist in any case where effluents exceed the limitation set forth in this permit. The Agency may consider such information in determining whether there is an actionable violation.
10. EPA will not utilize a notification of noncompliance in a criminal prosecution against the individual who gave the notification, except in a prosecution for perjury or for giving a false statement.
11. The discharge of corrosion inhibitors, biocides (other than chlorine) and/or dispersants without the prior written approval of the Regional Administrator, is prohibited.

POOR ORIGINAL