

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER & LIGHT COMPANY

AND


PENNSYLVANIA ELECTRIC COMPANY
THREE MILE ISLAND NUCLEAR STATION UNIT 1

Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request No. 82


This Technical Specification Change Request is submitted in support of Licensee's request to change Appendix A to Operating License No. DPR-50 for Three Mile Island Nuclear Station Unit 1. As a part of this request, proposed replacement pages for Appendix A are also included.

METROPOLITAN EDISON COMPANY

By


Vice President

Sworn and subscribed to me this 15th day of June, 1978.


Notary Public

GEORGE J. TROFFER
Notary Public, Reading, Berks Co.
My Commission Expires Jan. 25, 1982

7910310 529

1490 306

P

Three Mile Island Nuclear Station Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289

POOR ORIGINAL

Technical Specification Change Request No. 82

The licensee requests that the attached page replace page 6-11 of the existing Technical Specifications.

Reasons for Change Request

In our Small Break LOCA Submittal, GQL 0778, April 27, 1978, Met-Ed committed to submit Technical Specification Changes. This commitment was requested by the Commission to assure that appropriate operator action is taken in the event of a Small Break LOCA at TMI-1.

Safety Evaluation Justifying Change

This change provides a Technical Specification requirement for implementation of written procedures which include the operator action to be taken in the event of a Small Break LOCA. Procedures are currently in place at TMI-1 which include the operator action to be taken in the event of a Small Break LOCA. Because this change is administrative in nature, we have determined that:

- i) the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety, previously evaluated in the safety analysis report is not increased.
- ii) The possibility of an accident or malfunction of a different type than any evaluated previously in the safety analysis report is not created.
- iii) The margin of safety defined in the basis for any Technical Specification is not reduced.

License Amendment Classification (10 CFR 170.22)

Because this amendment was requested by the NRC and is being submitted for the convenience of the NRC, no remittance is required.

6.8 PROCEDURES

- 6.8.1 Written procedures and administrative policies shall be established, implemented and maintained that meet or exceed the requirements and recommendations of Sections 5.1 and 5.3 of ANSI N18.7-1972 and Appendix "A" of USNRC Regulatory Guide 1.33 November 1972 except as provided in 6.8.2 and 6.8.3 below.

Implementation of the Fire Protection Program shall be by means of written procedures.

Written procedures, which include the operator action to be taken in the event of a Small Break LOCA shall be implemented.

- 6.8.2 Each nuclear safety related procedure and administrative policy of 6.8.1 above, and changes thereto, shall be reviewed by the Plant Operations Review Committee and approved by the Unit Superintendent prior to implementation and periodically as may be set forth in each document.
- 6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:
- a. The intent of the original procedure is not altered.
 - b. The change is approved by two members of the plant management staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
 - c. The change is documented, reviewed by the Plant Operations Review Committee and approved by the Unit Superintendent within 7 days of implementation.