



METROPOLITAN EDISON COMPANY

SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

November 12, 1973

Mr. Eldon J. Brunner, Chief
Facility Test & Startup Branch
U. S. Atomic Energy Commission
Directorate of Regulatory Operations,
Region 1
631 Park Avenue
King of Prussia, PA 19406

SUBJECT: THREE MILE ISLAND NUCLEAR STATION
UNIT 1
DOCKET NO. 50-289


Dear Mr. Brunner:

Your letter of October 23, 1973 indicated that one of the activities being performed under our license appeared to be in violation of AEC requirements. The violation was listed as follows: "Preoperational Test Procedure TP 305/2 Reactor Protection System Response Time, was issued as an Official Field Copy in non-compliance with Test Instruction TI-18 Test Procedure Documents."

The following corrective action has been completed as of October 29, 1973:

- (1) The proper copy of TP 305/2 was issued to the field prior to commencing any section of the TP.
- (2) TI-18 has been revised to clarify requirements for preliminary review meetings, incorporation of Test Auditor Comments Relative to Test Procedural Approval Circuitry. RO:1 has reviewed this revision and has noted no apparent deficiencies.
- (3) A generic review has been conducted of TP's issued prior to approval of the TI-18 revision to insure that a similar problem did not exist in other TP's. This review has been completed with satisfactory results.

Very truly yours,


J. G. Miller
Vice President

asb

1584 315

7911070702