

# LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE: M O C C N 1  
LICENSE NUMBER: 0 0 0 - 0 0 0 0 0 0 - 0 0 0  
LICENSE TYPE: 4 1 1 1 1 1  
CAT 58: 5

REPORT SOURCE: L  
DOCKET NUMBER: 6 1 0 5 1 0 1 0 1 3 1 1 7  
EVENT DATE: 7 1 1 0 2 4 7 9  
REPORT DATE: 8 1 1 1 0 7 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES:  
During a reanalysis of the #11 and #12 Diesel Generator pipe supports

as required by IE Bulletin 79-14, it was discovered that the air

start system handers did not meet seismic requirements. To meet T.S.

3.8.1.1 started D/G's within one hour and ran them continuously, thereby

removing reliance upon diesel air start system. A similar occurrence

was reported in LER 79-47 (U-1).

SYSTEM CODE: E E  
CAUSE CODE: B  
CAUSE SUBCODE: A  
COMPONENT CODE: S U P P O R T  
COMP. SUBCODE: A  
VALVE SUBCODE: Z  
EVENT YEAR: 7 9  
SEQUENTIAL REPORT NO.: 0 6 1  
OCCURRENCE CODE: 0 1  
REPORT TYPE: T  
REVISION NO.: 0  
LER NO. REPORT NUMBER: 17  
ACTION TAKEN: F  
FUTURE ACTION: F  
EFFECT ON PLANT: Z  
SHUTDOWN METHOD: Z  
HOURS: 0 0 0  
ATTACHMENT SUBMITTED: N  
NPRD-4 FORM SUB.: N  
PRIME COMP. SUPPLIER: A  
COMPONENT MANUFACTURER: X 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS:  
The portion of the diesel air start system which had previously been

thought to have seismic supports has been reanalyzed and the existing

supports upgraded and new supports added. This is the only item of non-

compliance that was identified by the required IE Bulletin 79-14

Walkdowns.

FACILITY STATUS: E  
% POWER: 0 9 2  
OTHER STATUS: N/A  
METHOD OF DISCOVERY: D  
DISCOVERY DESCRIPTION: Visual Inspection  
ACTIVITY CONTENT RELEASED OF RELEASE: Z  
AMOUNT OF ACTIVITY: N/A  
LOCATION OF RELEASE: N/A

PERSONNEL EXPOSURES NUMBER: 0 0 0  
TYPE: Z  
DESCRIPTION: N/A

PERSONNEL INJURIES NUMBER: 0 0 0  
DESCRIPTION: N/A

LOSS OF OR DAMAGE TO FACILITY TYPE: Z  
DESCRIPTION: N/A

PUBLICITY ISSUED: Z  
DESCRIPTION: N/A

NAME OF PREPARER: R. P. Heibel

PHONE: (301) 234-7943

NRC USE ONLY