

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	N	P	I	N	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	LICENSEE CODE							14	LICENSE NUMBER										25	LICENSE TYPE					30	57 CAT		58

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During cold shutdown, inspection of pipe supports for cooling water piping
0 3 | modifications in Unit 1 containment revealed some supports were not built to
0 4 | specifications. The added piping is not QA Type I but must meet seismic criteria
0 5 | for protection of nearby Type I equipment. No effect on public health and safety.
0 6 |
0 7 |
0 8 |

7 8 9 80

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	9	W	A	B	C	S	U	P	O	R	T	B	Z				
7	8	9	10	11	12	13	13	14	15	16	17	18	19	20			
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	7	9	—	0	2	8	—	0	3	L	—	0					
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
B	X	C	Z	0	0	3	6	N	N	N	Z	X	9	9	9		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Installation error. Deficient supports were repaired. Contractor's QA Program

1 1 has been upgraded and will be more closely monitored by licensee.

1 2

1 3

1 4

7 8 9 80

FACILITY STATUS (28) G (1 5) 7 8 9
 % POWER (29) 0 0 0 10 11 12
 OTHER STATUS (30) NA 13 44
 METHOD OF DISCOVERY (31) C 45 46
 DISCOVERY DESCRIPTION (32) Inspection per IE Bulletin 79-14 47 80
 ACTIVITY CONTENT (33) Z (1 6) 7 8 9
 RELEASED OF RELEASE (34) Z (1 6) 7 8 9
 AMOUNT OF ACTIVITY (35) NA 10 11 44
 LOCATION OF RELEASE (36) NA 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)
7	8	9	11	12	13				80

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
1 8 0 0 0 (40) NA 1355 056

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 9 Z (42) NA

ISSUED 20 PUBLISHER NA (45) NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER A. A. Hunstad

PHONE: 612-388-4767

7911190 440